

Schedule of Equipment for NKF Dialysis Centres

The following is the schedule of equipment in the building which is non-exhaustive and the Contractor should verify and confirm on site:

1. Admiralty (22 nos.)

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
MAIN AREA							
Samsung	VCU A/1-1	AM060FXM	B1BZP3CHC00002W	VFCU A/1-1A VFCU A/1-1B VFCU A/1-3B VFCU A/1-1D	AM028FNN AM028FNN AM071FN4 AM028JNA	Y7CRPAGH600124R Y7CRPAGH600149D B6ABP3HJ400035X 0DCYPAGJ400073V	Wash Area (c/cassette) Trolley Bay (c/cassette) Main Area (c/cassette) Anteroom (w/m)
Samsung	VCU A/1-2	AM060FXM	B1BZP3CHC00003D	VFCU A/1-2A VFCU A/1-2B VFCU A/1-1C	AM071KN4 AM071KN4 AM036FNN	B6ABP3HJ400038L B6ABP3HJ400037K Y7CQPAGJ200050N	Main Area (c/cassette) TROLLEY BAY (c/cassette)
Samsung	VCU A/1-3	AM060FXM	B1BZP3CHC00004V	VFCU A/1-3A VFCU A/1-3C VFCU A/1-3D (Standby)	AM028FNN AM071KN4 AM045JNA	Y7CRPAGH6001852 B6ABP3HJ400036A 	Dialysis Room c/cassette) Main Area (c.cassette) Ro Room (24 hrs) - (w/m)
Samsung	VCU A/1-4	AM060FXM	B1BZP3AJ300003D	VFCU A/1-4A VFCU A/1-4B VFCU A/1-4C	AM071KN4 AM071KN4 AM028JNA	B6ABP3HJ400033J B6ABP3HH800013L 0DFYPAGJ400072B	Main Area (c/cassette) BME Room (w/m)
Samsung	VCU A/1-5	AM060FXM	B1BZP3CHC00001P	VFCU A/1-5A VFCU A/1-2C VFCU A/1-5B VFCU A/1-5C (Duty)	AM028FNN AM071KN4 AM028JNA AM045JNA	Y7CRPAGH600189Y 0DFYPAGJ400074J 	Clean Utility 2 (c/cassette) Main Area (c/cassette) Clean Utility 1 (w/m) Ro Room (24 hrs) - (w/m)
AREA B							
Samsung	VCU B/1-1	AM040FXM	BIBTP3GH500007B	VFCU B/1-1A VFCU B/1-1B VFCU B/1-2A	AM045FN4 AM056FN4 AM045KN4	 B6A2P3HJ200009K	Staff Locker (c/cassette) Activity Area (c/cassette)
Samsung	VCU B/1-2	AM040FXM	BIBTP3GH500006T	VFCU B/1-2B VFCU B/1-2C	AM045KN4 AM028FNN	B6A2P3HJ200007A Y7CRPAGH600128H	Activity Area (c/cassette) Consultation Rm (c/cassette)

Admiralty Mechanical Ventilation Fan List (07 nos.)

Fan No	Model	Type	CONTROL	Location	Remark
MAIN AREA					
EF A/1-1	FM 200	In-Line Centrifugal	FSP MV/A/1-1 Local Control Panel	Dialysis Room & Anteroom	Interlock with timer for auto on/off operation
TEF A/1-1	VF N-6	Propeller		H'cap Toilet	Interlock to Lighting switch
EF A/1-3	FM 160	In-Line Centrifugal	Fsp MV/A/1-2 Local Control Panel	Clean Utility 2	Interlock with timer for auto on/off operation
EF A/1-4	FM 125	In-Line Centrifugal		clean Utility 1	Interlock with timer for auto on/off operation
AREA B					
TEF B/1-1	VF N-6	Propeller		H'Cap Toilet	
TEF B/1-2	FM 100	In-Line Centrifugal	Fsp MV/B/1-1 Local Control Panel	Toilet	Interlock to Lighting Switch
TEF B/1-3	FM 100	In-Line Centrifugal		Shower/ Changing Area	

Schedule of Equipment for NKF Dialysis Centres

2. Aljunied (19 nos.)

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXQ10PAY15	E000742	1-1	FXFQ63PVE9	C001882	Station 5
				1-2	FXFQ63LUV1	E012764	Nurse Counter
				1-3	FXFQ63PVE9	C001943	Station 18
				1-4	FXFQ40LUV1	E004694	NM Office Waiting Area
				1-5	FXAQ25MAVE9	E009536	Store
Daikin	CU 2	RXMQ5AVE RXMQ5AVE	E003255 E003153	2-1	FXFQ63AVM	E001841	Station 1
				2-2		E001847	Station 13
				2-3	FXFQ63AVM	E001843	Station 10
				2-4	FXFQ63AVM	E000896	Patient Waiting Area
				2-5	FXAQ25PVE	E037573	DCCN Room
Daikin	CU 3-1	RKS35GVMG	E057037	3-1	FTKS35DVM	E188151	Bi-Carb Room
Daikin	CU 3-2	RKS35GVMG	E023662	3-1	FTKS35DVM	E076930	Re-Processing Room
Daikin	CU 4-1	3MKS71ESG	E021608	4-1	FTKS50FVM	E022003	Water Treatment Area
				4-2	FTKS25DVM	E052564	Technician Room
Daikin	CU 4-2	3MK75FV1N9		4-4	FTK25FVIN		Store Room
				4-5	FTK35FVIN		RO Plant Room
				4-6	FTK25FVIN		KRC, Waiting Area
Daikin	CU 5	R71LUV15	E030876	5-1	FHYC71KVE5	E014308	Staff Pantry
Daikin	CU 6	RKD35DAVM	E044089	6-1	FTKD35DVM	E127565	Water Treatment Room

3. Aljunied Office (05 nos.)

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
2 nos. of (22,000btu) Daikin Ceiling Cassette Unit / Condensing Unit - RZR60LVVM (E003764,E003801) + FCQ60LUV1 (E004540,E004536) 2 nos. of (18,000btu) Daikin Ceiling Cassette Unit / Condensing Unit - RZR50LVVM (E004117,E004130) + FCQ50LUV1 (E005398,E005292) 1 no. of (9,000btu) Daikin Wall Mounted Unit / Condensing Unit - RKS25GVMG (E027916) + FTKS25DVM (E160558)							

4. Ang Mo Kio II (19 nos.)

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 11	3MKS50ESG (Sys2)	E005935	11-2	FTKS25DVM	E038152	NM Room
				11-1	FTKS35DVM	E051333	Doctor Room
Daikin	CU 10	RZR60LVVM	E005332	10-1	FCQ60LUV1	E006195	Staff Area Corridor
Daikin	CU 9	3MKS50ESG (Sys2)	E005294	9-1	FTKS25DVM	E042065	Techician Room
				9-2	FTKS35DVM	E054315	Water Treatment Room
Daikin	CU 9A	R50GV1G	E003552	9-2A	FT50GV1G	E004215	Water Treatment Room
Daikin	CU 8	RZR50LVVM	E004425	8-1	FCQ50LUV1	E005324	Staff Pantry
Daikin	CU 7	RZR71LVVMG	E007985	7-1	FCQ71LUV1	E027434	Waiting Area
Daikin	CU 6	RKS35AVMG	E001671	6-2	FFQ35BV1B	E011380	Reprocessing Room
Daikin	CU 6A	RZR50LVVM	E005938	6-1	FCQ50LUV1	E006370	Store 2
Daikin	CU 5	R71LUV15	E031013	5-1	FHYC71KVE5	E014493	Patient Area (Outside Bi-Carb Room)
Daikin	CU 1	RXMQ5AVE	E002288	1-1	FXFQ63LUV1	E024676	Patient Area
				1-2	FXFQ63LUV1	E024675	Patient Area
Daikin	CU 2	RXMQ5AVE	E003256	2-1	FXFQ63AVM	E001836	Patient Area
				2-2	FHYC60KVE9	E001838	Patient Area
Daikin	CU 3	R125LUV15	E030259	3-1	FHYC60KVE9	E005827	Patient Area Station 7,8,9
				3-2	FHYC60KVE9	E005703	Patient Area (Nurse Counter)
Daikin	CU 4	5MKS100LSG	E005882	4-1	FFQ60BV1B	E007084	Patient Area Station 4,5,6
				4-2	FFQ60BV1B	E007091	Patient Area Station 24,25,26,27

Schedule of Equipment for NKF Dialysis Centres

5. Ang Mo Kio III (18 nos.)

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1A	RZR50LVVM	E005968	FCU 1	FCQ50LUV1	E006348	Re-Processing Room
Daikin	CU 2A	RKD35DVM	E004418	FCU 2	FTKD35DVM	E127195	Bi-Carb Room
Daikin	CU 3A	RKD25DVM	E002490	FCU 3	FTKD25DVM	E011455	Store
Daikin	CU 4A	RZR100MVMG	E006238	FCU 4	FCQ100KAVEA	E025086	Dialysis Station 1 ~ 3
Daikin	CU 5A	RZR100MVMG	E003370	FCU 5	FCQ100KAVEA	E016885	Dialysis Station 18 ~ 20
Daikin	CU 6A	RZR100LVVMG	E002394	FCU 6	FHYC100KVE5	E003419	Dialysis Station 7~ 9
Daikin	CU 7A	RZR100LVVMG	E001355	FCU 7	FCQ100LUV1	E006840	Dialysis Station 10 ~ 12
Daikin	CU 8A	R100LUV15	E005664	FCU 8	FCQ100LUV15	E010660	Dialysis Station 15 ~ 17
Daikin	CU 9A	RZR100LVVMG	E000110	FCU 9	FCQ100LUV1	E004767	Dialysis Stations 4 ~ 6
Daikin	CU 10A	RZR71LVVMG	E002024	FCU 10	FCQ71LUV1	E020066	Waiting Area
Daikin	CU 1B	RKD35DVM	E004425	FCU 1	FTKD35DVM	E012851	Doctor's Room
Daikin	CU 1B	R50GV1G	E002643	FCU 2	FHC50KVE5	E004331	Pantry / Staff Area
Daikin	CU 2B	RKD25DVM	E002397	FCU 3	FTKD25DVM	E011458	Technician's Room
Daikin	CU 2B	RZR50LVVM	E004014	FCU 4	FCQ50LUV1	E004782	Water Treatment Area
Daikin	CU 2B-1	RKS50GVVMG	E001487	FCU 4-1	FTKS50GVVMG	E015192	Water Treatment Room
Daikin	CU 3B	RZR60LVVM	E002392	FCU 5	FCQ60LUV1	E004292	Nurse Manager's Room
Daikin	CU 3B	RKS25GVVMG	E014920	FCU 6	FTKS25DVM	E080300	Lobby
Daikin	CU 4B	R60GV1G	E003122	FCU 7	FHC60KVE5	E002112	Large Store

6. Bukit Panjang I (18 nos.)

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RZR71LVVMG	E001817	1	FCQ71LUV1	E022347	Patient Area - Stn 10
Daikin	CU 2	RZR71LVVM	E002613	2	FCQ71LUV1	E008524	Patient Area - Stn 12 & 13
Daikin	CU 3	RZR71LUV1	E002835	3	FCQ71LUV1	E006457	Patient Area - Stn 9
Daikin	CU 4	RZR60LVVM	E004960	4	FCQ60LUV1	E005851	Re-Processing / Bi-Carb Room
Daikin	CU 5	RZR71LUV1	E004344	5	FCQ71LUV1	E008527	Patient Area - Stn 16
Daikin	CU 6	RZR50LVVM	E005743	6	FCQ50LUV1	E006310	Waiting Area
Daikin	CU 7	RZR71LVVMG	E008623	7	FCQ71LUV1	E028058	Patient Area - Stn 6
Daikin	CU 8	RZR71LVVMG	E008384	8	FCQ71LUV1	E028218	Patient Area - Stn 1 ~ 3
Toshiba	CU 9	RKS35GVVMG	E028341	9	FTKS35DVM	E093640	CNS
Toshiba	CU 10	RKS35GVVMG	E030237	10	FTKS35DVM	E091648	Doctor Room
Daikin	CU 11	RZR50LVVM	E009019	11	FCQ50LUV1	E008578	Staff Room (Pantry)
Daikin	CU 12	R50GV19	E007500	12	FHC50KVE5	E009974	Waiting Area (Office)
Daikin	CU 13	RZR50LVVM	E001311	13	FCQ50LUV1	E001437	Water Treatment Area
Daikin	CU 13A	R50GV1G	E003583	13A	FT50GV1G	E003575	Water Treatment Room
Daikin	CU 14	RZR50LVVM	E005039	14	FCQ50LUV1	E005854	BME Room
Toshiba	CU 15	RAS-M185AX	12100002	15	RAS10YKX	12300814	UPS Room
					RAS10YKX	12300842	UPS Room
Toshiba	CU 16	RAS-18UAX	12600881	16	RAS-18UKPX	12500813	Store Room

Schedule of Equipment for NKF Dialysis Centres

7. Bukit Panjang II (27 nos.)

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1-1	RXMQ4P	E003842	1-1/1	FXFQ25L	E004278	Waiting Area
				1-1/2	FXFQ32L	E002453	Dialysis Area
				1-1/3	FXFQ25L	E004276	Clean Utility Rm 1
				1-1/4	FXFQ32L	E002442	Dialysis Area
Daikin	CU 1-2	RXMQ5P	E004238	1-2/1	FXFQ25L	E004315	Waiting Area
				1-2/2	FXFQ32L	E005139	Dialysis Centre
				1-2/3	FXFQ32L	E005131	Dialysis Centre
				1-2/4	FXFQ32L	E005128	Dialysis Centre
Daikin	CU 1-3	3MKS71	E036869	1-3/1	FFQ35B	E009447	Dialysis Centre
				1-3/2	FFQ35B	E009527	Dialysis Centre
Daikin	CU 1-4	3MKS71	E035541	1-4/1	FFQ35B	E009675	Dialysis Centre
				1-4/2	FFQ35B	E009734	Dialysis Centre
Daikin	CU 1-5	3MKS71	E036987	1-5/1	FFQ35B	E009735	Dialysis centre
				1-5/2	FFQ35B	E009526	Dialysis centre
Daikin	CU 1-6	3MKS50	E015485	1-6/1	FFQ25B	E005609	Bi Carb Room
				1-6/2	FFQ25B	E005605	Processing Room
Daikin	CU 2-1	RXMQ4P	E003677	2-1/1	FXFQ25L	E004264	Corridor
				2-1/2	FXFQ32L	E005129	Doctor Room
				2-1/3	FXFQ32L	E002440	Staff Room
Daikin	CU 2-2	RXMQ4P	E003844	2-2/1	FXFQ32L	E005132	Staff Room
				2-2/2	FXFQ25L	E004280	Nurse Manager
				2-2/3	FXFQ25L	E004337	Lockers
				2-2/4	FXFQ25L	E004274	Corridor
Daikin	CU 2-3	RZR50LVVM	E001829	2-3/1	FCQ50L	E003345	R.O Room
Daikin	CU 2-4	RZR50LVVM	E001823	2-4/1	FCQ50L	E003341	R.O Room
Daikin	CU 2-5	3MKS50	E015614	2-5/1	FFQ25B	E005604	BME Room
				2-5/2	FFQ25B	E005603	Clean Utility Room 2

8. Bukit Batok (17 nos.)

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RZR71LVVMG	E009512	1	FCQ71LUV1	E029022	Patient Area (Near Stn 1 ~ 3 & Stn 14)
Daikin	CU 2	RZR71LVVMG	E009229	2	FCQ71LUV1	E029041	Patient Area (Near Stn 4 ~ 7)
Daikin	CU 3	RZR71LUV1	E004493	3	FCQ71LUV1	E008519	Patient Area (Near Stn 8 ~ 10)
Daikin	CU 4	RZR71LVVMG	E005286	4	FCQ71LUV1	E025669	Passageway o/s Reprocessing Room
Daikin	CU 5-1	RKS35GVVMG	E057506	5-1	FTKS35DVM	E188846	Bi-Carb Room
Daikin	CU 5-2	RKS35AVVMG	E001113	5-2	FFQ35BV1B	E005496	Water Treatment Room
Daikin	CU 5-2A	R50GV1G	E003472	5-2A	FT50GV1G	E003657	Water Treatment Room
Daikin	CU 6	R50GV19	2910009	6	FT50GAVE	29095536	BME Room
Daikin	CU 7	R35DV1	E065828	7-1	FT35DVM	E079975	Re-Processing Room
Daikin	CU 8	R50GV19	2910019	8	FHC50KVE5	2901113	Doctor / CNS Room
Daikin	CU 9	RZR50LVVM	E005969	9	FCQ50LUV1	E006342	Medical Store Room
Daikin	CU 10	R50GV19	2910008	10	FHC50KVE5	2901112	Gymnasium
Daikin	CU 11	RZR71LVVMG	E009820	11	FCQ71LUV1	E028445	Waiting Area
Daikin	CU 12-1	RZR50LVVM	E003975	12-1	FCQ50LUV1	E005281	Pantry
Daikin	CU 12-2	R35GJV1	2903738	12-2	FT35JV1	2906170	Staff Locker Room
Daikin	CU 13-1	R50GV19	2910048	13-1	FHC50KVE5	2901114	Passageway (outside Female Toilet)
Daikin	CU 13-2	RZR50LVVM	E005648	13-2	FCQ50LUV1	E006186	Passageway (outside Male Toilet)

Schedule of Equipment for NKF Dialysis Centres

9. Bukit Merah II (22 nos.)

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RZR50LVVM	E001210	1-1	FCQ50L	E002739	Reprocessing Room
Daikin	CU 2	3MKS71	E036237	2-1	FFQ25B	E004899	Clean Utility Room
				2-2	FFQ50B	E013686	Corridor
Daikin	CU 3	RXMQ5P	E003823	3-1	FXFQ63L	E014950	Nurse Station
				3-2	FXFQ50L	E009007	Nurse Station
Daikin	CU 4	RXMQ5P	E003915	4-1	FXFQ63L	E014930	Nurse Station
				4-2	FXFQ50L	E009004	Nurse Station
Daikin	CU 5	RKS35A	E001682	5-1	FFQ35B	E008554	Waiting Area
Daikin	CU 6	RKS35A	E001679	6-1	FFQ35B	E008446	Waiting Area
Daikin	CU 7	RKS35A	E001754	7-1	FFQ35B	E008443	BME
Daikin	CU 8	RKS50	E025236	8-1	FTKS50	E023247	R.O.
Daikin	CU 9	RKS50	E025292	9-1	FTKS50	E034100	R.O. (Standby)
Daikin	CU 10	5MKS100	E005865	10-1	FTKS50F	E023068	Doctor Room
				10-2	FTKS35	E098411	NM
Daikin	CU 11	3MKS71	E036177	11-1	FTKS25	E057486	Locker
				11-2	FFQ50B	E013690	Staff Room
Daikin	CU 12	3MKS71	E036246	12-1	FFQ35B	E008451	Clean Utility Room
				12-2	FFQ35B	E008521	Waiting Room
Daikin	CU 13	5MKS100	E007226	13-1	FFQ50B	E010509	Dialysis Area 2
		5MKS100		13-2	FFQ50B	E010555	Dialysis Area 2
Daikin	CU 14	RXMQ4AVE	E007576	14-1	FXFQ50AVM	E011028	Dialysis Area 2
		5MKS100		14-2	FXFQ50AVM	E011029	Dialysis Area 2

10. Bedok (20 nos.)

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXQ10PAY13 (VRV III)		1-2	FXFQ40PVE9	C005921	Near Station 1
				2-1	FXFQ40PVE9	C005925	Near Station 5
				1-6	FXFQ40PVE9	C005922	Counter Area
				1-5	FXFQ40PVE9	C005927	Near Station 13
				2-5	FXFQ40PVE9	C005926	Station 7-9
				1-4	FXAQ40MAVE	E012035	Store Room
Daikin	CU 2	RXQ10PAY13	E000884	2-2	FXFQ40PVE9	C002980	Near Station 12
				1-1	FXFQ40PVE9	C003158	Near Station 1
				2-4	FXFQ40PVE9	C003135	Station 13-14
				1-3	FXFQ40PVE9	C003159	Near Station 15
				2-6	FXFQ40PVE9	C003157	Station 1-3
				2-3	FXFQ40PVE9	C003155	Entrance Area
Daikin	CU 3	RXQ6TY1	E000123	3-1	FXFQ50LUV1	E005164	Waiting Area
				3-2	FXFQ40LUV1	E002911	DCCN Room
				3-3	FXAQ40PVE	E004522	Staff Tea Room
Daikin	A/C 3	RKS50GVMG	E043015	3	FTKS50GVMG	E041404	Water Treatment Area
Daikin	A/C 3A	R50GV1G	E003658	3A	FT50GV1G	E004214	Water Treatment Room
Daikin	A/C 4	R25GV1G	E900011	4	FT25DVM	E168917	Bi-Carb Room
Daikin	A/C 5	3MKS71ESG	E028362	5-1	FTKS35DVM	E068680	Technician Room
				5-2	FTKS35DVM	E068638	Re-Processing Room

Schedule of Equipment for NKF Dialysis Centres

11. Clementi (26 nos.)

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location	
Daikin	CU 1	RXMQ8AY1	E001713	1-1	FXFSQ63AVM	E000481	Treatment area	
				1-2	FXFSQ63AVM	E000534		
				1-3	FXFSQ63AVM	E000535		
				2-1	FXFSQ63AVM	E000678		
Daikin	CU 2	RXMQ8AY1	E001708	2-2	FXFSQ63AVM	E000677		
				2-3	FXFSQ63AVM	E000562		
				3-1	FXFSQ63AVM	E000561		
Daikin	CU 3	RXMQ10AYM	E001086	3-2	FXFSQ63AVM	E000480		Store Room DB Room
				3-3	FXFSQ63AVM	E000675		
				3-4	FXFQ25AVM	E002169		
				3-5	FXFQ25AVM	E044176		
Daikin	CU 4	RXMQ8AY1	E001709	4-1	FXFSQ63AVM	E000560		Treatment Area
				4-2	FXFSQ63AVM	E000563		
				4-3	FXFQ25AVM	E002084		
				4-4	FXFQ25AVM	E002166		
Daikin	CU 5	RXMQ8AY1	E001712	5-1	FXFQ25AVM	E002162	Open Passage Way Staff Rest Room Waiting Area Doctor Room Nurse Manager Room Water Treatment Room	
				5-2	FXFQ32AVM	E003273		
				5-3	FXFQ40AVM	E003305		
				5-4	FXFQ25AVM	E002163		
				5-5	FXFQ25AVM	E002085		
				5-6	FXFQ50AVM	E006442		
Daikin	CU 6	RXMQ6AYE	E003415	6-2	FXFQ32AVM	E003274	Staff Rest Room BME Room Corridor Store Room 1 Water Treatment Room	
				6-3	FXFQ25AVM	E002168		
				6-5	FXFQ25AVM	E002165		
				6-1	FXFQ32AVM	E003401		
				6-4	FXFQ50AVM	E005755		

Clementi Mechanical Ventilation Fan List (09 nos.)

Fan No	Brand	Model	Air Flow	Location	Remark
EAF-1	LTI	FM160	250	Wash Room	
EAF-2	LTI	FM160	145	Handicap 2	
EAF-3	LTI	FM160	145	Handicap 1	
EAF-4	LTI	FM161		Toilet	
EAF-4	LTI	FM160	210	Toilet	
FAF-1	LTI	FM315	440	Treatment Area	Interlock with fcus
FAF-2	LTI	FM315			Interlock with fcus
FAF-2	LTI	FM315	440	Treatment Area	Interlock with fcus
FAF-3	LTI	FM200	300	Store 2,3, Switch RM, Passage Wav	Interlock with fcus
FAF-4	LTI	FM200	350	Waiting, Corridor, Staff Rest, DR RM	Interlock with fcus
FAF-5	LTI	FM160	200	Store 1, Nurse MGR RM, BME RM	Interlock with fcus

Schedule of Equipment for NKF Dialysis Centres

12. CP1 (Level 1) (42 nos.)

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	VCU/1-1	RXQ12TAYM	E002972	VFU/1-1A	FXAQ25P	E019962	New Wash Area
				VFU/1-1B	FXFQ80S	C001766	New Haemodialysis Treatment
				VFU/1-1C	FXFQ40L	E006614	New BME Rm
				VFU/1-1D	FXFQ80S	C001778	New Haemodialysis Treatment
				VFU/1-1E	FXFQ80S	C001765	New Haemodialysis Treatment
Daikin	VCU/1-2	RXQ12TAYM	E002981	VFU/1-2A	FXFQ80S	C001779	New Haemodialysis Treatment
				VFU/1-2B	FXFQ40L	E008559	New Spare Equipment Rm (BME)
				VFU/1-2C	FXFQ80S	C001757	New Haemodialysis Treatment
				VFU/1-2D	FXFQ80S	C001769	
Daikin	VCU/1-3	RXQ10TAYM	E001701	VFU/1-3A	FXFQ80S	C001777	New Haemodialysis Treatment
				VFU/1-3B	FXFQ80S	C001775	
				VFU/1-3C	FXFQ80S	C001763	
Daikin	VCU/1-4	RXQ10TAYM	E001717	VFU/1-4A	FXFQ80S	C001771	
				VFU/1-4B	FXFQ80S	C001776	
				VFU/1-4C	FXFQ80S	C001786	
Daikin	VCU/1-5	RXQ8TAYM	E002192	VFU/1-5A	FXFQ40S	C000465	New Cohorting Area
				VFU/1-5B	FXFQ40S	C000467	
				VFU/1-5C	FXFQ40S	C000469	
				VFU/1-5D	FXFQ40S	C000471	
Daikin	VCU/1-6	RXQ22TAS	E003115, E001750	VFU/1-6A	FXFQ63S	C002078	New Waiting, Lift Lobby , Registration & Wheelchair Parking
				VFU/1-6B	FXFQ63S	C002079	
				VFU/1-6C	FXFQ63S	C002089	New Motorized Wheelchair Parking
				VFU/1-6E	FXFQ63L	E026463	
				VFU/1-6F	FXFQ25L	E007950	New Counselling Rm 1
				VFU/1-6G	FXFQ25L	E008262	New Counselling Rm 2
				VFU/1-6H	FXFQ32L	E009837	New Wheel Chair Parking
				VFU/1-6I	FXFQ25L	E008263	Corridor outside New IT Riser (MOF)
				VFU/1-6J	FXFQ32L	E010298	New Consulting Rm
				VFU/1-6K	FXAQ25P	E020085	New Pantry
				VFU/1-6L	FXAQ25P	E020088	New Additional Store (Pantry 2)
				VFU/1-6M	FXAQ25P	E019937	New Exchange Store (Clean Utility)
				VFU/1-6N	FXFQ25L	E008463	Corridor outside New H.T
Daikin				VCU/1-7	RXQ10TAYM	E001693	VFU/1-7A
	VFU/1-7B	FXFQ63S	C002090				
	VFU/1-7C	FXFQ63S	C002080				New Motorized Wheelchair Parking
	VFU/1-7D	FXFQ63L	E026469				
Daikin	SCU/1-1A	RZR140MYM	E003775	SFU/1-1A	FCQ140KA	E009485	New RO Rm
Daikin	SCU/1-1B	RZR140MYM	E003787	SFU/1-1B	FCQ140KA	E009479	
Daikin	SCU/1-2	RZR50LVVM	E006353	SFU/1-2	FCQ50L	E006684	Ante Room
Daikin	SCU/1-3	RZR50LVVM	E006326	SFU/1-3	FCQ50L	E006679	
Daikin	SCU/1-4	RKS25	E035631	SFU/1-4	FTKS25	E200765	MDF RM
Daikin	SCU/1-6	RKS25	E035579	SFU/1-6	FTKS25	E200789	New IT Riser

Schedule of Equipment for NKF Dialysis Centres

13. CP2 (Level 2) (35 nos.)

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	VCU/2-1	RXQ12TAYM	E000754	VFU/2-1A VFU/2-1B VFU/2-1C VFU/2-1D	FXFQ80S FXFQ80S FXFQ80S FXAQ25P	C001746 C001761 C001755 E020091	New Haemodialysis New Wash Area
Daikin	VCU/2-2	RXQ14TAYM	E001183	VFU/2-2A VFU/2-2B VFU/2-2C VFU/2-2D	FXFQ80S FXFQ80S FXFQ80S FXFQ80S	C001745 C001760 C001756 C001762	New Haemodialysis
Daikin	VCU/2-3	RXQ12TAYM	E002979	VFU/2-3A VFU/2-3B VFU/2-3C	FXFQ80S FXFQ80S FXFQ80S	C001759 C001751 C001754	New Haemodialysis
Daikin	VCU/2-4	RXQ12TAYM	E002988	VFU/2-3D VFU/2-4A VFU/2-4B VFU/2-4C VFU/2-4D	FXFQ40L FXFQ80S FXFQ80S FXFQ80S FXFQ40L	E009273 C001750 C001749 C001758 E009271	New Pallet Store New Haemodialysis New Pallet Store
Daikin	VCU/2-5	RXQ16TAYM	E001390	VFU/2-5A VFU/2-5B VFU/2-5C VFU/2-5D VFU/2-5E VFU/2-5F VFU/2-5G VFU/2-5H	FXFQ50S FXFQ50S FXFQ50S FXFQ40L FXFQ40L FXFQ40L FXAQ25P FXFQ40L	C000567 C000570 C000564 E009214 E009288 E009177 E034483 E009285	New Lift Lobby & Waiting Area Corridor Outside New Counselling Rm 1 New Nurse Pantry New Pantry Corridor Outside New H.T.
Daikin	VCU/2-6	RXQ16TAYM	E001391	VFU/2-6A VFU/2-6B VFU/2-6C VFU/2-6D VFU/2-6E VFU/2-6F VFU/2-6G VFU/2-6H VFU/2-6I VFU/2-6J	FXFQ50S FXFQ50S FXFQ50S FXFQ40L FXFQ40L FXFQ32L FXFQ32L FXFQ40L FXFQ32L FXFQ40L	C000557 C000559 C000569 E009210 E009215 E010398 E010401 E009270 E010453 E009275	New Lift Lobby & Waiting Area New Nurse Pantry New Counselling Rm 2 New Counselling Rm 1 Corridor Outside New IT Riser New Consultation Rm Corridor Outside New Physio Therapy
Daikin	SCU/2-1	RKS25	E035630	SFU/2-1	FTKS25	E207649	New IT Riser