

**Air-Con Equipment List for NKF Dialysis Centres**

**37. Upper Boon Keng (29 nos.)**

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Mitsubishi	CU 1A	MXY4A38VAP2	801732	FCU 1A-1 FCU 1A-2 FCU 1A-3	PLARP35BA PLARP35BA PLARP35BA	86A00008 86A00007 86A00014	Reception Office Space Pantry
Mitsubishi	CU 2A	MXY3A28VAR5	8008067T	FCU 2A	PLARP35BA	85A00006	Satff Corner
Mitsubishi	CU 3A	MXY3A28VAR5	8008181T	FCU 3A	PLARP35BA	86A00006	Consultation Room
Mitsubishi	CU 4A	MXY3A28VAR5	8008179T	FCU 4A-1 FCU 4A-2	PLARP35BA PLARP35BA	86A00001 86A00013	Corridor Corridor
Mitsubishi	CU 5A	MXY3A28VAR5	8008068T	FCU 5A-1 FCU 5A-2 FCU 5A-3	MSXYGA10VAR MSXYGA10VAR MSXYGA10VAR	8015451T 8015432T 8015429T	BME Water Treatment Room Store
Daikin	CU 5A-1	R50BV1	E124305	FCU 5A-4	FT50FVM	E106890	Water Treatment Room
Daikin	CU 1B	RZR50LVVM	E000694	FCU 1B	FCQ50LUV1	E002482	Waiting Area
Mitsubishi	CU 2B	MXY3A28VAR5	8008096T	FCU 2B	PLARP50BA	87A00011	Patient Area - Stn 18
Mitsubishi	CU 3B	MXY3A28VAR5	8008128T	FCU 3B	PLARP50BA	87A00020	Patient Area - Stn 1
Mitsubishi	CU 4B	MXY3A28VAR5	8008077T	FCU 4B	PLARP50BA	87A00008	Patient Area - Stn 16
Mitsubishi	CU 5B	RZR71LVVMG	E007730	FCU5B	FCQ71LUV1	E027707	Patient Area - Stn 3
Mitsubishi	CU 6B	MXY3A28VAR5	8008069T	FCU 6B	PLARP50BA	87A00018	Patient Area - Stn 15
Mitsubishi	CU 7B	MXY3A28VAR5	8004669T	FCU 7B	PLARP50BA	87A00007	Patient Area - Stn 6
Mitsubishi	CU 8B	RZR71LVVMG	E007518	FCU 8B	FCQ71LUV1	E027363	Patient Area - Stn 14
Mitsubishi	CU 9B	MXY3A28VAR5	8008203T	FCU 9B	PLARP50BA	87A00009	Patient Area - Stn 11
Mitsubishi	CU 10B	MXY3A28VAR5	8008130T	FCU 10B	PLARP50BA	88A00026	Patient Area - Stn 8
Mitsubishi	CU 11B	MXY3A28VAR5	8008145T	FCU 11B	PLARP50BA	87A00010	Patient Area - Near Reprocessing Room
Mitsubishi	CU 13B	MXY3A28VAR5	8008215T	FCU 13B	PLARP35BA	86A00005	Nurse Counter
Mitsubishi	CU 14B	MXY3A28VAR5	8008078T	FCU 14B-1 FCU14B-2	MSXYGA10VAR MSXYGA10VAR	8015211T 8015228T	NM Room Utility Room
Mitsubishi	CU 15B	MXY3A28VAR5	8004644T	FCU 15B	MSXYGA10VAR	8015437T	Dialysis Room
Mitsubishi	CU 16B	MXY3A28VAR5	8008204T	FCU 16B	PLARP35BA	86A00009	Bi-Carb Room
Mitsubishi	CU 17B	MXY3A28VAR7	4009012T	FCU 17B	PLARP35BAR1	33A00501	Re-Use Room
Mitsubishi	CU 18B	MXY3A28VAR5	8008201T	FCU 18B	MSXYGA10VAR	8015145T	Storage

**38. UBI (22 nos.)**

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXMQ6		FCU 1-1 FCU 1-2 FCU 1-3 FCU 1-4	FXFQ32L FXFQ25L FXFQ25L FXFQ63L		Staff Lounge (c/cassette) Doctor/NM Room (c/cassette) TV/Reading Area (c/cassette) Exercise Area (c/cassette)
Daikin	CU 2	RXMQ6		FCU 2-1 FCU 2-2 FCU 2-3 FCU 2-4	FXFQ32L FXFQ25L FXFQ25L FXFQ63L		Staff Lounge (c/cassette) TV/Reading Area (c/cassette)  Exercise Area (c/cassette)
Daikin	CU 3	RXMQ4		FCU 3-1 FCU 3-2 FCU 3-3	FXFQ25L FXFQ25L FXAQ20P		BME Room (c/cassette) R.O Room (c/cassette) Clean Utility (w/mounted)
Daikin	CU 4	RXMQ5		FCU 4-1 FCU 4-2 FCU 4-3	FXFQ25L FXFQ50P FXFQ50P		R.O Room (c/cassette) Nurse Counter/Holding (c/cassette)
Daikin	CU 5	RXMQ8		FCU 5-1 FCU 5-2 FCU 5-3 FCU 5-4	FXFQ50L FXFQ50L FXFQ50L FXFQ50L		Nurse Counter/Holding (c/cassette)
Daikin	CU 6	RXMQ4		FCU 6-1 FCU 6-2 FCU 6-3 FCU 6-4	FXFQ25L FXFQ25L FXAQ20P FXAQ20P		Trolley Bay (c/cassette)  Observation Room (w/mounted) Isolation Room 9 (w/mounted)

**Air-Con Equipment List for NKF Dialysis Centres**

**39. West Coast (22 nos.)**

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXMQ4AVE	E004010	FCU 1 FCU 2	FXFQ40SVM FXFQ40SVM	C000463 C000458	Waiting Area (c/cassette) Dialysis Area (c/cassette)
Daikin	CU 2	RXMQ4AVE	E004011	FCU 2-2 FCU 3-1	FXFQ40SVM FXFQ40SVM	C000462 C000464	Dialysis Area (c/cassette) Dialysis Area (c/cassette)
Daikin	CU 3	RXMQ5AVE	E002412	FCU 3-2 FCU 3-3 FCU 4-1	FXFQ40SVM FXFQ40SVM FXFQ40SVM	C000461 C000466 C000438	Dialysis Area (c/cassette) Dialysis Area (c/cassette) Dialysis Area (c/cassette)
Daikin	CU 4	RXMQ5AVE	E002370	FCU 4-2 FCU 4-3 FCU 5-2	FXFQ40SVM FXFQ40SVM FXFQ40SVM	C000457 C000440 C000468	Dialysis Area (c/cassette) Dialysis Area (c/cassette) Dialysis Area (c/cassette)
Daikin	CU 5	RZR50LVVM	E006102	FCU 5	FCQ50LUV1	E006402	Nurse Station (c/cassette)
Daikin	CU 6	RKS25GVMG	E034025	FCU 6	FFQ25BV1B	E007692	Store Room (c/cassette)
Daikin	CU 7	RXMQ4AVE	E004120	FCU 7 FCU 8	FXFQ32LUV1 FXAQ50PVE	E009050 E028871	BME Room (c/cassette) Ro Room (c/cassette)
Daikin	CU 8	RXMQ4AVE	E004128	FCU 9 FCU 10-1	FXAQ50PVE FXFQ50LUV1	E028878 E016734	Ro Room (wall mounted) Patient Main Waiting (c/cassette)
Daikin	CU 9	RXMQ5AVE	E002383	FCU 10-2 FCU 11 FCU 12	FXFQ50LUV1 FXFQ50LUV1 FXAQ25PVE	E016739 E016742 E032288	Patient Main Waiting (c/cassette) C/U Room (c/cassette) NM Room
Daikin	CU 10	RXMQ5AVE	E002402	FCU 13 FCU 14 FCU 15	FXFQ32LUV1 FXFQ32LUV1 FXFQ50LUV1	E009046 E009047 E016737	Doctor Room (c/cassette) Corridor (c/cassette) Staff Room (c/cassette)

**West Coast Mechanical Ventilation Fan List (09 nos.)**

Fan No	Model	Type	CONTROL	Location	Remark
EAF 1-1	RS125L	CIL	Int.Lock	Toilets	
EAF 1-2	RS125L	CIL	Int.Lock	Toilets	
EAF 1-3	RS125L	CIL	Int.Lock	Handicap Toilet	
EAF 1-4	RS125L	CIL	Int.Lock	Toilets	
EAF 1-5	RS125L	CIL	Int.Lock	Wash Area	
FAF 1-1	RS125L	CIL	Int.Lock	Corridor	
FAF 1-1	RS125L	CIL	Int.Lock	Patient Main Waiting Area	
FAF 1-3	RS125L	CIL	Int.Lock	Waiting Area	
FAF 1-3	RS125L	CIL	Int.Lock	Entrance beside Main D/B cabinet	

**Air-Con Equipment List for NKF Dialysis Centres**

**40. Woodlands I (28 nos.)**

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	5MKS100LSG	E005346	1-1	FTKS50FVM	E023762	Doctor / DCCN Room (w/m)
				1-2	FTKS50FVM	E023768	Pantry / Walkway (w/m)
				1-3	FTKS50FVM	E023832	BME Room(w/m)
Daikin	CU 2	4MKS80ESG	E016408	2-1	FTKS50FVM	E033293	Pantry Walk Way (w/m)
				2-2	FTKS50FVM	E033155	Walk Way (w/m)
				2-3	FTKS50FVM	E033715	Consultation Room (w/m)
Daikin	CU 3 CU 3A CU 3B	RZR60LVVM	E000631	3-1	FCQ60LUV1	E001824	Water Treatment Room (c/cassette)
		RZR60LVVM	E000633	3-2	FCQ60LUV1	E001826	Waiting Area (w/m)
		R50BV1	E124422	3-3	FT50 FVM	E106892	Water Treatment Room (w/m)
Daikin	CU 4	4MKS80ESG(Sys 2)	E013854	4-1	FFQ50BV1B	E0022496	Pantry (c/cassette)
				4-2	FFQ50BV1B9	E009156	Store Area(c/cassette)
Daikin	CU 5	RKS35AVMG	E002121	5	FFQ35BV1B9	E011140	IT Room (c.cassette)
Daikin	CU 6A	RZR71LVVMG	E003134	6-1	FCQ71LUV1	E022344	Re-Processing & Bi-Carb Room (c/cassette)
Daikin	CU 7	RZR71LWM	E000366	7-1	FCQ71LUV1	E011969	Waiting Area
Daikin	CU 8	RXMQ4AVE	E007457	8-1	FXFQ50AVM	E011214	Waiting Area (c/cassette)
				8-2	FXFQ50AVM	E011212	Patient Area 1,2 (c/cassette)
Daikin	CU 9	5MKS100LSG	E006031	9-1	FFQ60BV1B9	E007680	Patient Area 19,20 (c/cassette)
				9-2	FFQ60BV1B9	E007644	Counter
Daikin	CU 10	5MKS100LSG(Sys 2)	E001492	10-1	FFQ60BV1B	E004942	Patient Area 16 (c/cassette)
				10-2	FFQ60BV1B	E006407	Patient Area 18 (c/cassette)
Daikin	CU 11	RXMQ6AAVEG	E000152	11-1	FXFQ80AVM	E020205	Patient Area 3,4 (c/cassette)
				11-2	FXFQ80AVM	E020194	Toilet Opposite (c/cassette)
Daikin	CU 12	RXMQ5AVE	E001885	12-1	FXFQ63LUV1	E020542	Patient Area 5,6 (c/cassette)
				12-2	FXFQ63LUV1	E020502	Patient Area 7 (c/cassette)
Daikin	CU 13	R125LUY15(Sys 2)	E033344	13-1	FHYC60KVE9	E005971	Patient Area 9,10 (c/cassette)
				13-2	FHYC60KVE9	E006085	Patient Area 11 (c/cassette)
Daikin	CU 14	RXMQ5AVE	E001889	14-1	FXFQ63LUV1	E020497	Patient Area 14,15 (c/cassette)
				14-2	FXFQ63LUV1	E020534	Patient Area 12,13 (c/cassette)

**41. Woodlands II (21 nos.)**

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	13A	3MKS75HVENE	C000122	13A	FTKE35BSG	E001994	Corridor (w/m)
				4A	FTKE35BSG	E4905981	Staff Area Entrance (w/m)
Daikin	2A	RKS35AVMG	E001477	2A	FFQ35BV1B5	E008355	Re-Processing Room (c/cassette)
Daikin	3A	RKS25GVVMG	E014189	3A	FTKS25DVME	E091488	Technician Room (w/m)
Daikin	5A	RKS60AVMG	E000559	5A	FFQ60BV1B	E003368	Patient Area 9 ~10 & 14~16 (c/cassette)
Daikin	6A	RZR60LVVM	E001200	6A	FCQ60LUV1	E002405	Patient Area 7 & 18 (c/cassette)
Daikin	7A	RKS60AVMG	E006399	7A	FFQ60BV1B	E007051	Patient Area 4 & 5 (c/cassette)
Daikin	8A	RZR60LVVM	E005664	8A	FCQ60LUV1	E007051	Patient Area 12 & 13 (c/cassette)
Daikin	9A	RZR60LVVM	E001199	9A	FCQ60LUV1	E002441	Patient Area 2 & 3 (c/cassette)
Daikin	10A	RZR60LVVM	E006611	10A	FCQ60LUV1	E006833	Patient Area 1 (c/cassette)
Daikin	11A	RZR50LUV1	E001927	11A	FCQ50LUV1	E008490	Waiting Area (c/cassette)
Daikin	12A	RZR50LVVM	E008718	12A	FCQ50LUV1	E001773	Waiting Area (c/cassette)
Daikin	1B	3MKS71FSG	E006967	5B	FTKS25DVM	E141975	Nurse Manager Room (w/m)
				1B	FTKS35DVM	E113949	Consultation Room (w/m)
Daikin	4B	RZR50LUV1	E001549	4B	FCQ50LUV1	E001686	Water Treatment Room (w/m)
Daikin	4B-1	R50BV1	E124474	4B-1	FT50FVM	E106809	Water Treatment Room (w/m)
Daikin	8B	3MKS71FSG	E021847	8B	FTKS35DVM	E154201	Isolation room (w/m)
				6B	FTKS35DVM	E154202	Isolation room (w/m)
Daikin	7B	R50GV19	E002008	7B	FHC50KVE	4901884	Store Room (c/cassette)
Daikin	2B	RKS35AVMG	E001936	2B	FFQ35BV1V9	E010214	Pantry (c/cassette)
Daikin	3B	RKS25GVVMG	E039273	3B	FTKS25DVM	E224455	Bi Carb Room (w/m)

**42. Yishun I (13 nos.)**

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 3	R35GV1G	E000344	3	FT35DVM	E109238	Water Treatment Room (w/m)
Daikin	CU 4	RKD35DAVM	E007716	4	FTKD35DVM	E050382	Water Treatment Room (w/m)
Daikin	CU 1	RXQ10TY1	E000393	1-1	FXFQ32LUV1	E003696	DCCN Room (c/cassette)
				1-2	FXFQ63LUV1	E011228	Patient Area-Near Nure Couter(c/cassette)
				1-3	FXFQ63LUV1	E011230	Patient Area-Re-Processing Rm(c/cassette)
				1-4	FXFQ32LUV1	E003693	Bi Carb Room (c/cassette)
				1-5	FXFQ40LUV1	E003697	Waiting Area (c/cassette)
				1-6	FXFQ40LUV1	E003695	Staff Room (c/cassette)
Daikin	CU 5	RKS50GVVMG	E016083	5	FTKS50GVVMG	E014929	Reprocessing room(w/m)
Daikin	CU 2	RXQ8TY1	E002370	2-1	FXFQ63LUV1	E012671	Patient Area - Near Stn 3 (c/cassette)
				2-2	FXFQ63LUV1	E012674	Patient Area - Stn 11 (c/cassette)
				2-3	FXFQ63LUV1	E012669	Waiting Area (c/cassette)
				2-4	FXFQ25LUV1	E004366	Technician Room (c/cassette)

**Air-Con Equipment List for NKF Dialysis Centres**

**43. Yishun II (24 nos.)**

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1A	RKS35AVMG	E001543	1A	FFQ35BV1B	E008581	Waiting Area
Daikin	CU 1B	RKS35AVMG	E001555	1B	FFQ35BV1B	E008586	Waiting Area
Daikin	CU 2	RXMQ4PVEE	E003225	2-1	FXFQ50LVE	E006754	Nurse Station
				2-2	FXFQ50LVE	E006748	Nurse Station
Daikin	CU 3	RXMQ5PVEE	E003317	3-1	FXFQ63PVE	E011108	Nurse Station
				3-2	FXFQ63PVE	E011107	Nurse Station
Daikin	CU 4	RXMQ4PVEE	E003222	4-1	FXFQ50LVE	E006802	Nurse Station
				4-2	FXFQ50LVE	E006796	Nurse Station
Daikin	CU 5	3MKS71ESGE	E034843	5-1	FFQ35BV1B	E008597	Nurse Station
				5-2	FFQ35BV1B	E008590	Nurse Station
Daikin	CU 6	RKS25GVMG	E014529	6	FTKS25DVM	E077143	Nurse Manager Room
Daikin	CU 7	RZR50LVVM	E000344	7	FCQ50LUV1	E002479	Re-Processing Room
Daikin	CU 8	RKS35AVMG	E001544	8	FFQ35BV1B	E008596	Bi-Carb Room
Daikin	CU 9	RKS35GVMG	E022870	9	FTKS35DVM	E084173	Store
Daikin	CU 10	3MKS71ESGE	E034842	10-1	FTKS25DVM	E076762	Changing Room
				10-2	FTKS35DVM	E084144	Consultation Room
Daikin	CU 11	3MKS71ESGE	E034845	11-1	FFQ35BV1B	E008583	Waiting/ Corridor
				11-2	FFQ35BV1B	E008591	Staff Room
Daikin	CU 12	3MKS71ESGE	E035048	12-1	FFQ35BV1B	E008593	Training cum Staff Room
				12-2	FFQ35BV1B	E008589	Training cum Staff Room
Daikin	CU 13	RKS35GVMG	E022869	13	FTKS35DVM	E084184	BME Room
Daikin	CU 14	RKS50GVMG	E019893	14	FTKS50GVMG	E019101	Plant Room (Duty)
Daikin	CU 15	RKS50GVMG	E019888	15	FTKS50GVMG	E020105	Plant Room (Standby)
Daikin	CU 16	RKS35AVMG	E001542	16	FFQ35BV1B	E008587	Compactor Store Room

**44. Yishun III (22 nos.)**

Dialysis Centre	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	5MKS100		1-1	FFQ35B(W)	E010549	Trolley Rm
				1-2	FTKS25	E139068	Clean Utility 1
				1-3	FTKS25	E139077	Ante Rm
				1-4	FFQ25B(W)	E006012	Isolation Rm
Daikin	CU 2	5MKS100	E008357	2-1	FFQ50B(W)	E014539	Walkway
				2-2	FFQ50B(W)	E014630	Corridor
Daikin	CU 3	RZR71LVVMG		3-1	FCQ71L(W)		Dialysis Area
Daikin	CU 4	RXMQ5P		4-1	FXFQ63L(W)	E015562	Dialysis Area
				4-2	FXFQ63L(W)	E018858	Dialysis Area
Daikin	CU 5	RZR71LVVMG	E002607	5	FCQ71LUV1		Waiting Area/Nurse Counter
Daikin	CU 6	RXMQ5P		6-1	FXFQ63L(W)	E018579	Dialysis Area
				6-2	FXFQ63L(W)	E018581	Dialysis Area
Daikin	CU 7	3MKS71		7-1	FTKS50F		RO Rm
				7-2	FTKS25		Clean Utility 2
Daikin	CU 8	5MKS100	E008384	8-1	FTKS50F		RO Rm
				8-2	FFQ35B(W)	E010621	BME Rm
Daikin	CU 9	5MKS100		9-1	FFQ50B(W)		Gaming/ Eating Area
				9-2	FFQ35B(W)		Exercise Area
Daikin	CU 10	5MKS100		10-1	FFQ35B(W)		Doctor/ NMR Rm
				10-2	FFQ50B(W)		Reading/Com. Area
Daikin	CU 11	5MKS100		11-1	FFQ60(W)		Rest Rm
				11-2	FTKS25		Hot Dest