

ACMV List for NKF Dialysis Centres

The following is a non-exhaustive list of ACMV in the NKF premises. The Contractor should verify and confirm these on site.

1. 204 Marsiling DC (28 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXMQ6AVE	E002257	FCU 1-1 FCU 1-2 FCU 1-3 FCU 1-4 FCU 1-5	FXFQ50LUV1 FXFQ25LUV1 FXFQ32LUV1 FXFQ32LUV1 FXFQ25LUV1	E017348 E007662 E010196 E010206 E007660	Water Treatment Room BME Room Waiting Area (outside toilet) Waiting Area (near glass door) Nurse Manager's Room
Daikin	CU 2	RXMQ6AVE	E002104	FCU 2-1 FCU 2-2 FCU 2-3 FCU 2-4 FCU 2-5	FXFQ50LUV1 FXFQ25LUV1 FXFQ25LUV1 FXFQ25LUV1 FXFQ32LUV1	E017347 E007658 E007670 E007667 E010201	Water Treatment Room (near door) Staff Rest Room Staff Rest Room Clean Utilities Room Consultation Room
Daikin	CU 3	RXMQ4AVE	E004486	FCU 3-1 FCU 3-2	FXFQ50LUV1 FXFQ50LUV1	E017823 E017872	Holding Area near Door Holding Area Outside Toilet
Daikin	CU 4	RXMQ4AAVEG	E0013832	FCU 4-1 FCU 4-2	FXFQ50AVM FXFQ50AVM	E029508 E029630	Treatment Area (Station 2) Treatment Area (Station 19)
Daikin	CU 5	RXMQ4AVE (1HP)	E004443	FCU 5-1 FCU 5-2	FXFQ50SVM FXFQ50SVM	C001377 C001368	Treatment Area (Station 3 & 4) Treatment Area ( Station 17 to 21)
Daikin	CU 6	RXMQ6AVE (1HP)	E002752	FCU 6-1 FCU 6-2 FCU 6-3 FCU 6-4	FXFQ50SVM FXFQ25SVM FXFQ50SVM FXFQ25SVM	C001367 C000299 C001378 C000303	Treatment Area (Station 6) Treatment Area (Station 16 to 22) Nurse Counter Near MATV Rack
Daikin	CU 7	RXMQ5AVE (1HP)	E002178	FCU 7-1 FCU 7-2 FCU 7-3	FXFQ50SVM FXFQ50SVM FXFQ50SVM	C001373 C001366 C001375	Treatment Area (Station 7) Treatment Area (Station 15) Treatment Area (Station 10)
Daikin	CU 8	RXMQ6AVE (1HP)	E002659	FCU 8-1 FCU 8-2 FCU 8-3 FCU 8-4 FCU 8-5	FXAQ20PVE FXAQ20PVE FXAQ20PVE FXFQ32LUV1 FXFQ25LUV1	E030138 E030116 E030143 E010260 E008448	Treatment Area (Station 12) Ante Room (Near sink) Clean Utilities Room Trolley Bay Trolley Bay (near door)

2. 365 Woodlands DC (20 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1B	MKS65QVMG	E011011	FCU 13A FCU 4A	CTKS25QVM CTKS25QVM	E050600 E050596	Staff Rest Room (corridor) Staff Rest Room (entrance)
Daikin	CU 3A	RKS25JVE8	E001126	FCU 3A	FTKE25BSG	4905853	Bi Carb Room
Daikin	CU 5A	RZR60LVVM	E006930	FCU 5A	FCQ60LUV1	E007320	Treatment Area (Station 9,10,14,16)
Daikin	CU 6A	RXF60CV1G	E000408	FCU 6A	FCF60CVMG	E000534	Treatment Area (Station 7 &18)
Daikin	CU 7A	RKS60AVMG	E000603	FCU 7A	FFQ60BV1B	E002724	Treatment Area (Station 4 & 5)
Daikin	CU 8A	RZR60LVVM	E006399	FCU 8A	FCQ60LUV1	E007051	Treatment Area (Station 12 &13)
Daikin	CU 9A	RXF71CV1G	E0037670	FCU 9A	FCF71CVMG	E003566D	Treatment Area (Station 2 & 3)
Daikin	CU 10A	RZR60LVVM	E006611	FCU 10A	FCQ60LUV1	E006833	Treatment Area (Station 1)
Daikin	CU 11A	RZR50LVVM	E008718	FCU 11A	FCQ50LUV1	E008490	Waiting Area (near toilet)
Daikin	CU 12A	RZF50CV1G	E001212	FCU 12A	FCF50CVMG	E001221	Waiting Area (near weighing scale)
Daikin	CU 8B	3MKS71FSG	E006967	FCU 1B FCU 5B	FTKS 35 DVM FTKS 25 DVM	E113949 E141975	Consultation Room (w/m) Nurse Manager Room (w/m)
Daikin	CU 4B	RZF50CV1G	E001808M	FCU 4B	FCF50CVMG	E001736E	Water Treatment Room
Daikin	CU 4B-1	RKS50LVMG	E001845	FCU 4B-1	FTKS50LVMG	E001761	Water Treatment Room
Daikin	CU 13A	3MKS71FSG	E021847	FCU 8B FCU 6B	FTKS35DVM FTKS35DVM	E154201 E154202	Clean Utilities Room Treatment Area
Daikin	CU 7B	RZR50LVVM	E009408	FCU 7B	FCQ50LUV1	E009008	Clean Utilities Room
Daikin	CU 2B	RZR50LVVM	E011139	FCU 2B	FCQ50LUV1	E010343	Staff Rest Room
Daikin	CU 3B	RKS25GVMG	E039273	FCU 3B	FTKS25DVM	E224455	BME Room

3. 761 Woodlands DC (21 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXMQ5AAVEG	E001599	FCU 1-1 FCU 1-2 FCU 1-3	FXZQ25BVM FXFQ63AVM FXAQ25ARVEG	E000120 E039393 0000498	Treatment Area (Trolley Bay) Treatment Area (Station 6 & 12) Outside Deialysis Room
Samsung	CU 2	AM060FXMDEH/EU	B1BZP3CHC00003D	FCU 2-1 FCU 2-2 FCU 2-3	AM071KN4DEH/EU AM071KN4DEH/EU AM036FNNDEH/EU	B6ABP3HJ400038L B6ABP3HJ400037K Y7CQPAGJ200050N	Treatment Area (Station 8 & 10) Treatment Area (Station 2 & 16) Storeroom
Samsung	CU 3	AM060FXMDEH/EU	B1BZP3CHC00004V	FCU 3-1 FCU 3-2 FCU 3-3	AM028FNNDEH/EU AM071KN4DEH/EU AM056JNVDKH/EU	Y7CRPAGH600185Z B6ABP3HJ400036A 0DG7PAGHC00045B	Dialysis Room Treatment Area (Station 1 & 19) Water Treatment Room (near door)
Samsung	CU 4	AM060FXMDEH/EU	B1BZP3AJ300003D	FCU 4-1 FCU 4-2 FCU 4-3	AM071KN4DEH/EU AM071KN4DEH/EU AM028JNVDKH/EU	B6ABP3HJ400033J B6ABP3HH800013L 0DFYPAGJ400072B	Treatment Area (Station 4 & 14) Outside Patient Toilet BME Room
Samsung	CU 5	AM060FXMDEH/EU	B1BZP3CHC00001P	FCU 5-1 FCU 5-2 FCU 5-3 FCU 5-4	AM028FNNDEH/EU AM071KN4DEH/EU AM028JNVDKH/EU AM056JNVDKH/EU	Y7CRPAGH600189Y B6ABP3HH800015P 0DFYPAGJ400074J 0DG7PAGHC00038Y	Clean Utilities 2 Nurse Counter Clean Utilities 1 Water Treatment Room
Daikin	CU 6	RXMQ4AAVEG	E001404	FCU 6-1 FCU 6-2	FXFQ50AVM FXFQ40AVM	E029496 E015618	Staff Rest Room OA Counter
Samsung	CU 7	AM040FXMDEH/EU	B1BTP3GH500006T	FCU 7-1 FCU 7-2 FCU 7-3	AM045KN4DEH/EU AM045KN4DEH/EU AM028FNNDEH/EU	B6A2P3HJ200009K B6A2P3HJ200007A Y7CRPAGH600149	Activity near OA Counter Activity near Toilet Consultation/NM Room

761 Woodlands Mechanical Ventilation Fan List (07 nos.)

Fan No	Model	Air Flow	Control	Location	Remark
EF A/1-1	FM 200		FSP MV/A/1-1	Dialysis Room &	Interlock with timer for
TEF A/1-1	VF N-6		Fsp MV/A/1-2 Control Panel	Local H'cap Toilet	Interlock to Lighting
EF A/1-3	FM 160			Clean Utility 2	Interlock with timer for
EF A/1-4	FM 125			clean Utility 1	Interlock with timer for
TEF B/1-1	VF N-6		Fsp MV/B/1-1 Control Panel	Local H'Cap Toilet	Interlock to Lighting Switch
TEF B/1-2	FM 100			Toilet	
TEF B/1-3	FM 100			Shower/ Changing Area	

4. 825 Woodlands DC (27 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	4MKS80ESG	E016408	FCU 1-1 FCU 1-2 FCU 1-3	FTKS 50 FVM FTKS 50 FVM FTKS 50 FVM	E023762 E023768 E023832	Consultation Room Corridor (outside BME room) BME Room
Daikin	CU 2	MKM85VVMG	E018196	FCU 2-1 FCU 2-2	CTKM71VVMG CTKM35VVMG	E004004 E015391	Corridor to Staff Rest Room Counselling Room
Daikin	CU 3	RZR60LVVM	E000631	FCU 3-1	FCQ60LUV1	E001824	Water Treatment Room
Daikin	CU 3A	RZR60LVVM	E000633	FCU 3-2	FCQ60LUV1	E001826	Waiting Area 2
Daikin	CU 3B	RKS50LVMG	E000719	FCU 3-3	FTKS50LVMG	E001096	Water Treatment Room
Daikin	CU 4	RXMQ5AAVEG	E001584	FCU 4-1 FCU 4-2	FXFQ50AVM FXFQ50AVM	E024373 E027001	Staff Rest Room Clean Utilities Room
Daikin	CU 5	RKS35AVMG	E002121	FCU 5	FFQ35BV1B9	E011140	IT Room
Daikin	CU6A	RZR71LVVMG	E003134	FCU 6-1	FCQ71LUV1	E022344	Clean Utilities Room
Daikin	CU 7	RZF71CV1G	E002179	FCU 7-1	FCF71VMG	E002285	Waiting Area 1
Daikin	CU 8	RXMQ4AVE	E007457	FCU 8-2 FCU 8-1	FXFQ50AVM FXFQ50AVM	E011212 E011214	Waiting Area 1 Treatment Area (Station 1 & 2)
Daikin	CU 9	RXMQ5AAVEG	E001221	FCU 9-2 FCU 9-1	FXFQ63AVM FXFQ63AVM	E032585 E033027	Treatment Area (Station 19 & 20) Nurses Counter
Daikin	CU 10	RXMQ5AAVEG	E000484	FCU 10-1 FCU 10-2	FXFQ63AVM FXFQ63AVM	E024935 E024938	Treatment Area (Station 9 &10) Treatment Area (Station 11)
Daikin	CU 11	RXMQ6AAVEG	E000152	FCU 11-1 FCU 11-2	FXFQ80AVM FXFQ80AVM	E020194 E020205	Treatment Area (Station 3 & 4) Outside Toilet
Daikin	CU 12	RXMQ5AVE	E001885	FCU 12-1 FCU 12-2	FXFQ63LUV1 FXFQ63LUV1	E020542 E020502	Treatment Area {Station 4 & 5) Treatment Area (Station 6 & 7)
Daikin	CU 13	RXMQ5AAVEG	E000530	FCU 13-1 FCU 13-2	FXFQ63AVM FXFQ63AVM	E025761 E025717	Treatment Area (Station 16) Treatment Area (Station 18)
Daikin	CU 14	RXMQ5AVE	E001889	FCU 14-1 FCU 14-2	FXFQ63LUV1 FXFQ63LUV1	E020497 E020534	Treatment Area (Station 12) Treatment Area (Station 14)



5. 203 Yishun DC (12 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1A	RXMQ6AAVEG	E000108	FCU 1-1 FCU 1-2 FCU 1-3	FXFQ32AVM FXFQ40AVM FXFQ40AVM	E008805 E006587 E006592	Consultation Room Staff Rest Room Waiting Area
Daikin	CU 1B	RXMQ6AAVEG	E000109	FCU 1-1 FCU 1-2 FCU 1-3	FXFQ63AVM FXFQ63AVM FXFQ32AVM	E025080 E025081 E008800	Treatment Area (Station 4) Treatment Area (Station 9) Clean Utilities Room
Daikin	CU 2	RXQ8AYMG	E000372	FCU 2-1 FCU 2-2 FCU 2-3 FCU 2-4	FXFQ63AVM FXFQ63AVM FXFQ63AVM FXFQ25AVM	E032588 E032586 E033208 E008745	Treatment Area (Station 3) Treatment Area (Station 7 to 11) Waiting Area BME Room
Daikin	CU 3	RKM35XVMG	E001389	FCU 3	FTKM35XVMG	E001531	Water Treatment Room
Daikin	CU 4	RKM35XVMG	E000868	FCU 4	FTKM35XVMG	E001518	Water Treatment Room

6. 639 Yishun DC (24 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1A	RZR50LVVM	E011155	FCU 1A	FCQ50LUV1	E010341	Waiting Area 1 (near toilet)
Daikin	CU 1B	RKS35AVMG	E001555	FCU 1B	FFQ35BV1B	E008586	Waiting Area 1 (entrance)
Daikin	CU 2	RXMQ4AAVEG	E000820	FCU 2-1 FCU 2-2	FXFQ50AVM FXFQ50AVM	E020646 E020642	Treatment Area (Station 15 & 16) Treatment Area (Station 11 & 12)
Daikin	CU 3	RXMQ5AAVEG	E001665	FCU 3-1 FCU 3-2	FXFQ63AVM FXFQ63AVM	E039498 E039903	Treatment Area (Station 18 & 19) Treatment Area (Station 8 & 9)
Daikin	CU 4	RXMQ4PAVE	E007275	FCU 4-1 FCU 4-2	FXFQ50LVE FXFQ50LVE	E006802 E006796	Nurse Counter Treatment Area (Station 6 & 7)
Daikin	CU 5	RXMQ4AAVEG	E000725	FCU 5-1 FCU 5-2	FXFQ50AVM FXFQ50AVM	E020640 E020644	Treatment Area (Station 3 & 4) Treatment Area (Station 1 & 2)
Daikin	CU 6	RKS25GVMG	E014529	FCU 6	FTKS25DVM	E077013	Nurse Manager's Room
Daikin	CU 7	RZR50LVVM	E009390	FCU 7	FCQ50LUV1	E009010	Clean Utilioies Room
Daikin	CU 8	RKS35AVMG	E001544	FCU 8	FFQ35BV1B	E008590	Clean Utilities Room
Daikin	CU 9	RKS35GVMG	E022870	FCU 9	FTKS35DVM	E084173	Clean Utilities Room
Daikin	CU 10	MKM50VVMG	E012668	FCU 10-1 FCU 10-2	CTKM25VVMG CTKM35VVMG	E074064 E018266	Changing Room Consultation Room
Daikin	CU 11	RXMQ4AAVEG	E001415	FCU 11-1 FCU 11-2	FXFQ32AVM FXFQ32AVM	E014965 E015109	Waiting Area 2 (corridor) Staff Room Room (near pantry door)
Daikin	CU 12	RXMQ4AAVEG	E001417	FCU 12-1 FCU 12-2	FXFQ32AVM FXFQ32AVM	E015105 E014968	Staff Room Room (near whiteboard) Staff Room Room (near back door)
Daikin	CU 13	RKS35GVMG	E022869	FCU 13	FTKS35DVM	E084184	BME Room
Daikin	CU 14	RKS50GVMG	E019893	FCU 14	FTKS50GVMG	E019101	Water Treatment Room
Daikin	CU 15	RKS50GVMG	E019888	FCU 15	FTKS50GVMG	E020105	Water Treatment Room
Daikin	CU 16	RKS35AVMG	E001542	FCU 16	FFQ35BV1B	E008587	Compactor Store Room

7. 840 Yishun DC (22 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXMQ5AAVEG	E001230	FCU 1-1 FCU 1-2 FCU 1-3 FCU 1-4	FXFQ32AVM FXAQ25ARVEG FXAQ25ARVEG FXFQ32AVM	E011072 0000233 0000422 E011077	Trolley Room Clean Utilities 1 Ante Room Single Room
Daikin	CU 2	RXMQ4AAVEG	E000633	FCU 2-1 FCU 2-2	FXFQ50AVM FXFQ50AVM	E020768 E020648	Walkway (to back Ent) Corridor (outside toilet)
Daikin	CU 3	RCF71CV1G	E003635	FCU 3-1	FCF71CVMG	E003143	Treatment Area (Station1 & 2)
Daikin	CU 4	RXMQ5AVE	E000774	FCU 4-1 FCU 4-2	FXFQ63LUV1 FXFQ63LUV2	E018581 E018579	Treatment Area (Station 11 & 12) Treatment Area (Station 5 & 6)
Daikin	CU 5	RZR71CV1G	E001677	FCU 5	FCF71CVMG	E001727	Waiting Area/Nurse Counter
Daikin	CU 6	RXMQ5AAVEG	E002152	FCU 6-1 FCU 6-2	FXFQ63AVM FXFQ63AVM	E045271 E043527	Treatment Area (Station 9 & 10) Treatment Area (Station 3 & 4)
Daikin	CU 7	3MKS71	E040799	FCU 7-1 FCU 7-2	FTKS60FVM FTKS25DVM	E014576 E139094	Water Treatment Room Clean Utilities 2
Daikin	CU 8	5MKS100	E008384	FCU 8-1 FCU 8-2	FTKS50FVM FFQ35BV1B	E040914 E010621	Water Treatment Room BME Room
Daikin	CU 9	RXMQ4AAVEG	E000474	FCU 9-1 FCU 9-2	FXFQ50AVM FXFQ32AVM	E019733 E009894	Gaming/ Eating Area Exercise Area
Daikin	CU 10	RXMQ4AAVEG	E000545	FCU 10-1 FCU 10-2	FXFQ32AVM FXFQ50AVM	E009792 E019560	Consultation Room Reading/Com. Area
Daikin	CU 11	RXMQ4AAVEG	E001054	FCU 11-1 FCU 11-2	FXFQ63AVM FXAQ25ARVEG	E024794 0000482	Staff Rest Room Hot Dest (behind OA)

8. Yishun Community Hospital DC (35 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	No CU. Chilled water supply link to building			FCU 1	FWMJC9BV1	K000761	Clean Utilities 1
				FCU 2	FWMJC9BV1	K000760	Clean Utilities 1
				FCU 3	FWMJC8BV1	K000719	Ante Room 2
				FCU 4	FWMJC8BV1	K000678	Single Room 2
				FCU 5	FWMJCC4BV1	K001654	Corrdior
				FCU 6	FWMJCC4BV1	K001610	Corrdior
				FCU 7	FWMJCC2BV1	K000810	Ante Room 1
				FCU 8	FWMJCC4BV1	K001607	Single Room 1
				FCU 9	FWMJC9BV1	K000762	Clean Utilities 2
				FCU 10	FWMJCC4BV1	K001608	Switch Room
				FCU 11	FWMJCC4BV1	K001603	Corridor
				FCU 12	FWMJCC4BV1	K001600	Sample Collection
				FCU 13	FWMJC8BV1	K000713	Staff Rest Room
				FCU 14	FWMJC8BV1	K000715	Staff Rest Room
				FCU 15	FWMJCC4BV1	K001601	Waiting Area
				FCU 16	FWMJC8BV1	K001599	Waiting Area
				FCU 17	FWMJCC4BV1	K001599	Consultation Room
				FCU 18	FWMJC8BV1	K000720	Nurse Counter
				FCU 19	FWMJC8BV1	K000670	Nurse Counter
				FCU 20	FWMJC8BV1	K000717	Treatment Area
				FCU 21	FWMJC8BV1	K000724	Treatment Area
				FCU 22	FWMJC8BV1	K000716	Treatment Area
				FCU 23	FWMJC8BV1	K000721	Treatment Area
				FCU 24	FWMJC8BV1	K000712	Treatment Area
				FCU 25	FWMJC8BV1	K000723	Treatment Area
				FCU 26	FWMJC8BV1	K000667	Treatment Area
				FCU 27	FWMJC8BV1	K000722	Treatment Area
				FCU 28	FWMJC8BV1	K000714	Treatment Area
				FCU 29	FWMJC8BV1	K000668	Treatment Area
				FCU 30	FWMJC8BV1	K000711	Treatment Area
				FCU 31	FWMJC9BV1	K000763	Water Treatment Room
				FCU 32	FWMJC9BV1	K000759	Water Treatment Room
				FCU 33	FWMJCC4BV1	K001602	BME Room
				FCU 34	FWMJC8BV1	K000718	Pertoneal Dialysis Room
				FCU 35	FWMJC8BV1	K000725	Pertoneal Dialysis Room

ACMV List for NKF Dialysis Centres

9. 565 Ang Mo Kio DC (18 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1A	RZF50CV1G	E001033	FCU 1	FCF50CVMG	E000930	Clean Utilities Room
Daikin	CU 2A	RKD35		FCU 2	FT35DVM	E127195	Bi-Carb Room
Daikin	CU 3A	RK50GVMG	E041795	FCU 3	FTKS50GVMG	E041373	Storeroom
Daikin	CU 4A	RZF100CV1G	E001880	FCU 4	FCF100CVMG	E002007	Treatment Area (Stations 1 to 3)
Daikin	CU 5A	RZR100MVMG	E003370	FCU 5	FCQ100KAVEA	E016885	Treatment Area (Stations 19 & 20)
Daikin	CU 6A	RZR100LVVMG	E002394	FCU 6	FCQ100LUV1	E010660	Treatment Area
Daikin	CU 7A	RZF100CV1G	E001456	FCU 7	FCF100CVMG	E001768	Treatment Area (Stations 10 to 12)
Daikin	CU 8A	R100		FCU 8	FHYC 100		Treatment Area
Daikin	CU 9A	RZR100LVVMG	E000110	FCU 9	FCQ100LUV1	E004767	Treatment Area (Station 4 to 6)
Daikin	CU 10A	RZR71LVVMG	E002020	FCU 10	FCQ71LUV1	E020066	Waiting Area
Daikin	CU 1B	RKD35		FCU 1	FTKD35		Consultation Room
Daikin	CU 1B	RZF50CV1G	E000657	FCU 2	FCF50CVMG	E000709	Staff Rest Room
Dakin	CU 2B	RKD25		FCU 3	FTKD25		BME Room
Daikin	CU 2B	RZF50CV1G	E001244	FCU 4	FCF50CVMG	E001244	Water Treatment Room
Daikin	CU 2B -1	RKS 50GVMG	E01487	FCU4-1	FTKS 50GVMG	E015192	Water Treatment Room
Daikin	CU 3B	RKD25		FCU 5	FTKD25		Nurse Manager's Room
Daikin	CU 3B	RKS25 GVMG	E014920	FCU 6	FTKS25 DVM	E080300	Lobby
Daikin	CU 4B	RZR60LVVM	E006903	FCU 7	FCQ60LUV1	E007248	Store Room Area 2

10. 633 Ang Mo Kio DC (19 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXMQ5AVE	E002288	FCU 1-1 FCU 1-2	FXFQ63LUV1 FXFQ63LUV1	E024675 E024676	Treatment Area (Station 16 to19) Treatment Area (Station 20 to 22)
Daikin	CU 2	RXMQ5AVE	E003256	FCU 2-1 FCU 2-2	FXFQ63AVM FXFQ63AVM	E001838 E001836	Treatment Area (Station 13 &14) Treatment Area (Station 22 & 23)
Daikin	CU 3	RXMQ5AAVEG	E000458	FCU 3-1 FCU 3-2	FXFQ63AVM FXFQ63AVM	E025839 (TE) E025840 (TE)	Treatment Area (Station 7 to 9) Nurse Counter
Daikin	CU 4	5MKS100LSG	E005882	FCU 4-1 FCU 4-2	FFQ60BVIB FFQ60BVIB	E007084 E007091	Treatment Area (Station 4 to 6) Treatment Area (Station 24 to 27)
Daikin	CU5	RZF71CV1G	E002203	FCU 5-1	FCF71CVMG	E002402	Treatment Area (Stattion 1 to 3)
Daikin	CU 6	R71LUV15	E030892	FCU 6-2	FHC35KVE	8000195	Reprocessing Room
Daikin	CU 6A	RZF50CV1G	E001814J	FCU 6-1	FCF50CVMG	E0017409	Storeroom
Daikin	CU 7	RZF71CV1G	E003539L	FCU 7-1	FCF71CVMG	E0038307	Waiting Area 1
Daikin	CU 8	RZR50LVVM	E004425	FCU 8-1	FCQ50LUV1	E005324	Staff Rest Room
Daikin	CU 9	3MKS50ESG	E005294	FCU 9-1 FCU 9-2	FTKS25DVM FTKS35DVM	E042065 E052315	BME Room Water Treatment Room
Daikin	CU 9A	R50GV1G	E003552	FCU 9-2A	FT 50 GV1G	E004215	Water Treatment Room
Daikin	CU 10	R60GV1	7902812	FCU 10	FHC 60 KVE	8000720	Staff Area Corridor
Daikin	CU 11	3MKS50ESG	E005935	FCU 11-2 FCU 11-1	FTKS25DVM FTKS35DVM	E038152 E051333	Nurse Manager's Room Consultation Room



11. 114 Hougang DC (23 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXUQ18AYMG	E000186	FCU 1-1 FCU 1-2 FCU 1-3 FCU 1-4 FCU 1-5	FXFSQ80A FXFSQ80A FXFSQ80A FXFQ63A FXFQ32A	E002662 E002663 E002654 E012382 E012055	Treatment Area Treatment Area Treatment Area Clean Utilities Room MPR 1
Daikin	CU 2	RXUQ18AYMG	E000188	FCU 2-1 FCU 2-2 FCU 2-3 FCU 2-4 FCU 2-5 FCU 2-6	FXFSQ80A FXFSQ80A FXFSQ80A FXFQ32A FXFQ40A FXFQ40A	E002666 E002653 E002655 E008531 E012384 E012382	Treatment Area Treatment Area Treatment Area Single Room Consultation Room MPR 2
Daikin	CU 3	RXUQ18AYMG	E000187	FCU 3-1 FCU 3-2 FCU 3-3 FCU 3-4 FCU 3-5 FCU 3-6	FXFSQ80A FXFSQ80A FXFSQ80A FXFQ63A FXFQ50A FXFQ63A	E002660 E002648 E002657 E036832 E023440 E036835	Treatment Area Treatment Area Treatment Area Waiting Area Water Treatment Room Clean Utilities Room
Daikin	CU 4	RXUQ18AYMG	E000183	FCU 4-1 FCU 4-2 FCU 4-3 FCU 4-4 FCU 4-5 FCU 4-6	FXFSQ80A FXFSQ80A FXFSQ80A FXFQ63A FXFQ50A FXFQ63A	E002719 E002665 E002664 E036831 E023445 E036833	Treatment Area Treatment Area Treatment Area Waiting Area Water Treatment Room Clean Utilities Room

12. 628 Hougang DC (27 nos)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1A	RXMQ4AVE		FCU 1A-2	FXFQ50AVM	E007519	Activity Corner
Daikin	CU 1C	RXMQ4AVE	E006416	FCU 1C	FXFQ50AVM	E007672	Waiting Area
Daikin	CU 2A	RZR71LVVMG	E013185	FCU 2A	FCQ71LUV1	E31110	Treatment Area (Station 1 & 2)
Daikin	CU 3A	RZR71LVVMG	E006981	FCU 3A	FCQ71LUV1	E027203	Treatment Area (Station 4 & 5)
Daikin	CU 4A	RZR60LVVM	E004081	FCU 4A	FCQ60LUV1	E005110	Treatment Area (near sink)
Daikin	CU 5A	RZR60LVVM	E006947	FCU 5A	FCQ60LUV1	E007382	Treatment Area (Station 13 & 14)
Daikin	CU 6A	RZR71LVVMG	E010643	FCU 6A	FCQ71LUV1	E030030	Treatment Area (Station 6 & 7)
Daikin	CU 6C	RZR71LVVMG	E010638	FCU 6C	FCQ71LUV1	E030025	Treatment Area (Station 10 to 12)
Dainkin	CU 7A	RZF71CV1G	E001307	FCU 7A	FCF71CVMG	E001311	Treatment Area (Station 9)
Daikin	CU 8A	RZR60LVVM	E004078	FCU 8A	FCQ60LUV1	E005041	Treatment Area (near exit door)
Daikin	CU 9A	RZR71LVVMG	E006720	FCU 9A	FCQ71LUV1	E026789	Treatment Area (Station 15 & 16)
Toshiba	CU 10A	RAV SM562 AT-E		FCU 10A	RAVC SM562 UT-E		Dialysis Room
Diakin	CU 11A	RZR60LVVM	E005036	FCU 11A	FCQ60LUV1	E005923	Re-Processing Room
Daikin	CU 12A	RXMQ5AAVEG	E001088	FCU 12A-2 FCU 12A-3 FCU 12A-4	FXAQ50ARVEG FXAQ32ARVEG FXFQ50AVM	E000413 E0000578 E021169	Storage Nurse Manager's Room Nurse Counter
Daikin	CU 1B	5MKS100	E005466	FCU 1B-1 FCU 1B-2 FCU 1B-3	FTKS50FVM FTKS35DVM FTKS25DVM	E032070 E091612 E108828	Staff Counter & Common Wardrobe Consultation Room Activity Room
Toshiba	CU 2B	RAS-3M23YACV		FCU 2B-1 FCU 2B-2	RAS-M13NKCV RAS-M13NKCV		Counselling Room Staff Area Entrance
Daikin	CU 3B	RKM25YMG	E003235	FCU 3B	FTKM25XVMG	E002758	BME Room
Daikin	CU 4B	RZR71LVVMG	E007165	FCU 4B	FCQ71LUV1	E027286	Water Treatment Room
Daikin	CU 4B-1	R50 BV1	E124878	FCU 4B-1	FT 50 GV	E013089	Water Treatment Room
Toshiba	CU 5B	RAS-3M23YACV		FCU 5B-1 FCU 5B-2	RAS-M13NKCV		Common Corridor
Diakin	CU13A	RKS50GVMG	E026463	FCU 13A	FTKS50GVMG	E024744	Bi-carb room

13. Punggol DC (01 no.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Location: AHU/PC 2-2 Brand : Carrier Model : 39G2025H44GA04N9ANFT-7 Serial No: 4416M05026							

14. 201 Serangoon DC (16 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXMQ5AAVEG	E001039	FCU 1-1 FCU 1-2	FXFQ63AVM FXFQ63AVM	E031741 E031743	Treatment Area (Station 9) Treatment Area (Station 14)
Daikin	CU 2	RXQ10TY1	E000446	FCU 2-1 FCU 2-2 FCU 2-3 FCU 2-4 FCU 2-5 FCU 2-6	FXFQ63LUV1 FXFQ63LUV1 FXFQ40LUV1 FXAQ32PVE FXAQ32PVE FXAQ63PVE	E009120 E009122 E003304 E022572 E011363 E012059	Treatment Area (Station 3) Treatment Area (Station 17) Entrance Area Re-Processing Area BME Room Water Treatment Room
Daikin	CU 3	RXQ6TY1	E000949	FCU 3-1 FCU 3-2 FCU 3-3 FCU 3-4	FXAQ32PVE FXAQ40PVE FXAQ40PVE FXAQ40PVE	E015198 E015033 E015027 E015035	Staff Area Lobby Staff Rest Room Consultation Room Nurse Manager's Room
Daikin	CU 4	RKS50GVMG	E 040636	FCU 4-1	FTKS50GVMG	E038820	Water Treatment Room
Daikin	CU 5	RXMQ5AAVEG	E001016	FCU 5-1 FCU 5-2	FXFQ63AVM FXFQ63AVM	E031742 E031744	Treatment Area (Station 6) Nurse Counter
Dakin	CU 6	RZR71LVVMG	E010131	FCU 6-1	FCQ71LUV1	E029489	Store Room

ACMV List for NKF Dialysis Centres

19. 180 Pasir Ris DC (17 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RQQ10TYM	E001514	FCU 1-1 FCU 1-2 FCU 1-3 FCU 1-4	FXMQ63PVE FXMQ63PVE FXMQ63PVE FXMQ63PVE	E009909 E009913 E009914 E009910	Treatment Area (Station 4 & 5) Treatment Area (Station10 & 11) Treatment Area (Station 1 & 2) Entrance Area
Daikin	CU 2	RSX5KYI	6700920	FCU 2-1 FCU 2-2	FXFQ50LVE FXAQ40LVE5	C005967 E000938	Waiting Area 1 Clean Utilities Room
Daikin	CU 3	RXMQ5AAVEG	E000192	FCU 3-1 FCU 3-2 FCU 3-3	FXAQ25 FXAQ50 FXAQ50	E0000134 E0000133 E0000135	BME Room Water Treatment Room
Daikin	CU 4	R50BV1	E064298	FCU 4-1	FT50FVM	E068595	Water Treatment Room
Daikin	CU 5	RXUQ6AYM	E000187	FCU 5-1 FCU 5-2 FCU 5-3	FXFSQ50AVM FXFSQ40AVM FXFSQ50AVM	E000639 E000557 E000722	Outside Staff Toilet Main Entrance Treatment Area (Station 14 &15)
Daikin	CU 6	RXUQ6AYM	E000185	FCU 6-1 FCU 6-2 FCU 6-3 FCU 6-4	FXFSQ50AVM FXFSQ40AVM FXFSQ40AVM FXFSQ40AVM	E000688 E000558 E000556 E000561	Treatment Area (Station 14 &15) Treatment Area (Station 16 &17) Treatment Area (Station 18 &19) Consultation Room

20. 427 Pasir Ris DC (20 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU-1	RSUQ8AYM	E000184	FCU 1-1 FCU 1-2 FCU 1-3	FXFQ80AVM FXFQ63AVM FXFQ40AVM	E025972 E028833 E009147	Staff Rest Room Clean Utilities 1 Water Treatment Room
Daikin	CU-2	RXMQ6AAVEG	E000578	FCU 2-1 FCU 2-2 FCU 2-3 FCU 2-4	FXFQ32AVM FXAQ32ARVEG FXAQ32ARVEG FXFQ40AVM	E008074 E000279 E000274 E009718	BME Room Corridor CCTV/IT Room Water Treatment Room
Daikin	CU-3	RSUQ7AYM	E000108	FCU 3-1 FCU 3-2 FCU 3-3 FCU 3-4	FXFQ40AVM FXFQ40AVM FXFQ40AVM FXFQ32AVM	E009145 E009711 E009716 E009161	Waiting Area Waiting Area (Corrdior) Consultation Room Clean Utilities 2
Daikin	CU-4	RSUQ8AYM	E000182	FCU 4-1 FCU 4-2 FCU 4-3	FXFSQ63AVM FXFSQ63AVM FXFSQ63AVM	E002467 E002469 E002567	Treatment Area (Station 1) Treatment Area (Equipment parking) Treatment Area (Station 16)
Daikin	CU-5	RSUQ8AYM	E000165	FCU 5-1 FCU 5-2 FCU 5-3	FXFSQ63AVM FXFSQ63AVM FXFSQ63AVM	E002466 E002566 E002569	Nurse Counter Treatment Area (Station 14) Treatment Area (Standby machines)
Daikin	CU-6	RSUQ7AYM	E000107	FCU 6-1 FCU 6-2 FCU 6-3	FXFSQ63AVM FXFSQ63AVM FXFSQ40AVM	E001029 E002468 E002568	Treatment Area (Station 4 & 5) Treatment Area (Station 21) Multi Purpose Room

21. 101 Simei DC

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
The dialysis centre is currently undergoing retrofitting and is estimated to resume operations in July 2024							



22. 271 Tampines DC (23 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RZR71KUV1	E002246	FCU 1-1	FCQ71KVEA	C009865	Waiting Area
Daikin	CU 2	RXMQ5AAVEG	E001459	FCU 2-1 FCU 2-2	FXFQ50AVM FXFQ63AVM	E024297 E038314	Treatment Area Treatment Area
Daikin	CU 3	RXMQ5PVEE	E004546	FCU 3-1 FCU 3-2	FXFQ50PVE9 FXFQ63PVE9	E007517 E012615	Treatment Area Treatment Area
Daikin	CU 4	RXMQ5AVE	E002409	FCU 4-1 FCU 4-2	FXFQ50LUV1 FXFQ63LUV1	E016439 E024038	Treatment Area Treatment Area
Daikin	CU 5	RXMQ5PVEE	E001543	FCU 5-1 FCU 5-2	FXFQ50PVE9 FXFQ63PVE9	E000110 E039392	Treatment Area Treatment Area
Daikin	CU 7	RXMQAAVEG	E000435	FCU 7-1 FCU 7-3	FXFQ50AVM FXFQ50AVM	E018610 E018612	Treatment Area (Station 21 & 22) Trolley Bay
Daikin	CU 6-1	3MKS71ESGE	E034576	FCU 6-1	FTKS35DVM	E034576	Single Room
Daikin	CU 6-2	3MKS71ESGE	E014906	FCU 6-2	FTKS25DVM	E014906	Nurse Manager's Room
Daikin	CU 8A	RKS35GVMG	E000420	FCU 8A-1	FFQ 35BV1B9	E011415	Re-use room
Daikin	CU 8B	RKS25AVMG	E000337	FCU 8B-1	FFQ 25B	E001762	Bi-carb room
Daikin	CU 9	2MKS40FV1B	C006662	FCU 9-1 FCU 9-2	FTKS25DVM FTKS25DVM	E023574 E023507	Locker room Consultation Room
Daikin	CU 10	3MKS71ESGE	E000907	FCU 10-1 FCU 10-2	FFQ35BV1B FFQ35BV1B	E003002 E003252	Corridor Staff Rest Room
Daikin	CU 11	4MKS80FSG	E014517	FCU 11-1 FCU 11-2	FFQ60BV1B FTKS25DVM	E011526 E236380	Staff Rest Room BME Room
Daikin	CU 12	RKS35GVMG	E000393	FCU 12-1	FTKS35DVM	E236380	Water Treatment Room
Daikin	CU 13	RKS35GVMG	E000600	FCU 13-1	FTKS35DVM	E034667	Water Treatment Room

23. 935 Tampines DC (14 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXQ10TY1	E000557	FCU 1-1 FCU 1-2 FCU 1-3 FCU 1-4	FXMQ125PVE FXMQ125PVE FXAQ32PVE FXAQ32PVE	E030855 E030848 E015195 E015192	Treatment Area (Station 1 to 4, 12 to 15) Treatment Area (Sation 16 , 17 & 22) Consultation Room Staff Rest Room
Daikin	CU 2	RXQ12TY1	E003310	FCU 2-1 FCU 2-2 FCU 2-3 FCU 2-4	FXMQ125PVE FXSQ63PVE FXMQ125PVE FXAQ50PVE	E036840 E000760 E036841 E021775	Treatment Area (Station 5, 6, 9 to11) Passage Way Bi-Carb, Re-Pro, BME Storeroom
Daikin	CU 3	RZR125MYM	E005704	FCU 3	FCQ125KAVEA	E009768	Waiting Area
Daikin	CU 4	RZR100MYM	E001703	FCU 4	FCQ100KAVEA	E004248	Treatment Area (Station 18 to 21)
Daikin	CU 5-1	R 71 LUY 15	E013265	FCU 5-1	FHYC 71 KVE	E011855	Nursing Counter
Daikin	CU 5-2	RZR71LVVMG	E007366	FCU 5-2	FCQ71LUV1	E027411	Treatment Area (Station 8)
Daikin	CU 6	RKS60GVMG	E017505	FCU 6	FTKS60GVMG	E016689	Water Treatment Room
Daikin	CU 7	RKS35GVMG	E055374	FCU 7-1	FTKS35DVM	E184762	Treatment Area (Station 7)

24. 27 New Upper Changi DC (26 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RSUQ8AYM	E000135	FCU 1-1	FXFQ32A	E009890	Staff Rest room
				FCU 1-2	FXFQ25A	E008092	Clean Utilities 2
				FCU 1-3	FXFQ25A	E008087	BME Room
				FCU 1-4	FXFQ25A	E008090	Corridor
				FCU 1-5	FXFSQ40A	E000961	Treatment Area
				FCU 1-6	FXFSQ40A	E000960	Treatment Area
Daikin	CU 2	RSUQ8AYM	E000141	FCU 2-1	FXFQ50A	E019841	Water Treatment Room
				FCU 2-2	FXFQ25A	E008089	Staff Rest Room
				FCU 2-3	FXFQ32A	E010107	Clean Utilities 2
				FCU 2-4	FXFSQ40A	E001053	Treatment Area
				FCU 2-5	FXFSQ40A	E001054	Treatment Area
				FCU 2-6	FXAQ25A	E021883	AV/IT Equipment Room
Daikin	CU 3	RSUQ8AYM	E000135	FCU 3-1	FXFQ32A	E009889	Clean Utilities 1
				FCU 3-2	FXFSQ40A	E000959	Treatment Area
				FCU 3-3	FXFSQ40A	E001052	Treatment Area
				FCU 3-4	FXFSQ40A	E000962	Nurse Counter
				FCU 3-5	FXFQ32A	E009888	Waiting Area
Daikin	CU 4	RSUQ7AYM	E000146	FCU 4-1	FXFQ50A	E019835	Water Treatment Room
				FCU 4-2	FXFSQ40A	E001079	Treatment Area
				FCU 4-3	FXFSQ40A	E001055	Treatment Area
				FCU 4-4	FXFQ32A	E009893	Waiting Area
Daikin	CU 5	RSUQ7AYM	E000148	FCU 5-1	FXFQ32A	E009891	Clean Utilities 1
				FCU 5-2	FXFSQ40A	E000963	Treatment Area
				FCU 5-3	FXFSQ40A	E001056	Treatment Area
				FCU 5-4	FXFQ25A	E008088	Consultation Room
				FCU 5-5	FXFQ25A	E008085	Corridor

25. 105 Bedok DC (18 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU V1	RXMQ6AAVEG	E000390	FCU 1-1	FXFSQ63AVM	E001517	Treatment Area
				FCU 1-2	FXFSQ63AVM	E001530	Treatment Area
				FCU 1-3	FXFQ25AVM	E005878	Waiting Area
Daikin	CU V2	RXMQ6AAVEG	E000383	FCU 2-1	FXFSQ63A	E001528	Treatment Area
				FCU 2-2	FXFSQ63A	E001518	Treatment Area
				FCU 2-3	FXFSQ25A	E000197	Nurse Counter
Daikin	CU V3	RXMQ8AY1	E002797	FCU 3-1	FXFQ25AVM	E005852	Consultation Room
				FCU 3-2	FXFSQ63A	E001527	Treatment Area
				FCU 3-3	FXFSQ63A	E001549	Treatment Area
				FCU 3-4	FXFQ25AVM	E005837	Clean Utilities Room
				FCU 3-5	FXFQ25AVM	E005856	Waiting Area
Daikin	CU V4	RXMQ5AAVEG	E000486	FCU 4-1	FXFQ32AVM	E008431	Water Treatment Room
				FCU 4-2	FXFQ32AVM	E008429	Corridor
				FCU 4-3	FXFQ32AVM	E008411	Clean Utilities Room
				FCU 4-4	FXAQ25ARVEG	0000249	Switch Room
Daikin	CU V5	RXMQ5AAVEG	E000488	FCU 5-1	FXFQ32AVM	E008412	Water Treatment Room
				FCU 5-2	FXFQ40AVM	E008487	Staff Rest Room
				FCU 5-3	FXFQ32AVM	E008441	BME Room

ACMV List for NKF Dialysis Centres

26. 102 Aljunied DC (24 nos.)							
Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU V1	RXUQ10AYM	E000631	FCU 1-1	FXFSQ63AVM	E002935	Treatment Area
				FCU 1-2	FXFSQ63AVM	E003169	Treatment Area
				FCU 1-3	FXFSQ63AVM	E003403	Treatment Area
				FCU 1-4	FXFQ25AVM	E010288	Waiting Area
	CU V2	RXUQ10AYM	E000655	FCU 2-1	FXFSQ63AVM	E003361	Treatment Area
				FCU 2-2	FXFSQ63AVM	E003068	Treatment Area
				FCU 2-3	FXFSQ63AVM	E003036	Treatment Area
				FCU 2-4	FXFQ25AVM	E009813	Clean Utilities 1
Daikin	CU V3	RXUQ10AYM	E000680	FCU 3-1	FXFSQ63AVM	E003361	Treatment Area
				FCU 3-2	FXFSQ63AVM	E003170	Treatment Area
				FCU 3-3	FXFQ25AVM	E010287	Clean Utilities 1
				FCU 3-4	FXFSQ63AVM	E003401	Nurse Counter
				FCU 3-5	FXFQ25AVM	E010772	Waiting Area
Daikin	CU V4	RXUQ10AYM	E000676	FCU 4-1	FXFQ25AVM	E013307	Consultation Room
				FCU 4-2	FXFQ40AVM	1010287	Staff Rest Area
				FCU 4-3	FXFQ25AVM	E009814	Water Treatment Room
				FCU 4-4	FXFQ25AVM	E010798	BME Room
				FCU 4-5	FXFQ32AVM	E014265	Clean Utility 2
				FCU 4-6	FXFQ50AVM	E027810	Room 1
Daikin	CU V5	RXUQ10AYM	E000657	FCU 5-1	FXFQ40AVM	E013287	Staff Rest Area
				FCU 5-2	FXFQ50AVM	E027814	Internal Corridor
				FCU 5-3	FXFQ25AVM	E010771	Water Treatment Room
				FCU 5-4	FXFQ33AVM	E014260	Clean Utility Room 2
				FCU 5-5	FXFQ50AVM	E027811	Room 2

Mechanical Ventilation Fan List (21 nos.)					
Fan No	Model	Air Flow	Control	Location	Remark
TEAF-1-1		200	CP-TEAF-1	Handicap Toilet	
EAF-1		150	CP-EAF-1	Wash Area	
EAF-2		100	CP-EAF-2	Changing Room	
TEAF-2		200	CP-TEAF-2	Staff Toilet	
EAF-3		80	CP-EAF-3	Janitor Room	
EAF-4		300	CP-EAF-4	Switch Room	
EAF-5		350	CP-EAF-5	AV/IT Equipment Room	
FAF-1		110	CP-FAF-1	Clean Utilities 1	
		180		Treatment Area	
FAF-2		240	CP-FAF-2	Treatment Area	
		50		Nurse Counter	
		50		Waiting Area	
		50		RO Plant Room	Interlock FCU with bypass switch (switch located above ceiling near fan control panel)
		50		Consultation Room	
		50		Corridor	
FAF-3		100	CP-FAF-3	BME Room	
		50		General Waste Room	
		50		AV/IT Equipment Room	
		50		Clean Utilities 2	
		50		Room 1	
		50		Room 2	



27. 43 Bendemeer DC (25 nos.)							
Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	4MKS80	E022607	FCU 1-1	FXFQ25B	E004889	Waiting Area
				FCU 1-2	FXFQ60B	E007054	Waiting Area
Daikin	CU 2	5MKS100	E005608	FCU 2-1	FXFQ60B	E007045	Nurse Counter
				FCU 2-2	FXFQ60B	E006373	Treatment Area (Station 21)
Daikin	CU 3	RXMQ5AAVEG	E001565	FCU 3-1	FXFQ63AVM	E028546	Treatment Area (Station 2)
				FCU 3-2	FXFQ63AVM	E035451	Treatment Area (Station 5)
Daikin	CU 4	5MKS100	E005456	FCU 4-1	FXFQ60B	E006405	Treatment Area (Station 8)
				FCU 4-2	FXFQ60B	E017749	Treatment Area (Station 11)
Daikin	CU 5	5MKS100	E005601	FCU 5-1	FXFQ63AVM	E021539	Nurse Counter
				FCU 5-2	FXFQ63AVM	E021540	Treatment Area (Heb B Station)
Daikin	CU 6	RXMQ5AAVEG	E001539	FCU 6-1	FXFQ63AVM	E040072	Treatment Area (Station 14)
				FCU 6-2	FXFQ63AVM	E040074	Treatment Area (Station 17)
Daikin	CU 7	3MKS71	E037758	FCU 7-1	FXFQ50B	E012800	Reprocessing Room
				FCU 7-2	FTKS25	E101715	Bi Carb Room
Daikin	CU 8	3MKS71	E0387843	FCU 8-1	FFQ25B	E004842	Clean Utility Room
				FCU 8-2	FTKS35	E099206	A Solution Room/Store
Daikin	CU 9	4MKS80	E022653	FCU 9-1	FTKS25	E100354	Locker Area
				FCU 9-2	FFQ60B	E007058	Staff Rest Room
Daikin	CU 10	4MKS80	E022680	FCU 10-1	FFQ35B	E008329	Consultation Room
				FCU 10-2	FFQ25B	E004888	Nurse Manager's Room
				FCU 10-3	FFQ25B	E004906	Waiting Area
Daikin	CU 11	3MKS71	E038041	FCU 11-1	FFQ35B	E008245	BME Room
				FCU 11-2	FFQ35B	E008342	Clean Utility Room
Daikin	CU 12	RKS50GVMG	E023441	FCU 12	FTKS50GVMGQ35B	E017751	Water Treatment Room
Daikin	CU 13	RKS50GVMG	E023438	FCU13	FTKS50GVMGQ35B	E017749	Water Treatment Room

28. NKF Centre (123 nos.)							
Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1-1			FCU 1-1-1			Level 1 - Office 1
				FCU 1-1-2			Level 1 - Office 2
				FCU 1-1-3			Level 1 - Office 3
				FCU 1-1-4			Level 1 - Café
Daikin	CU 1-2			FCU 1-2-1 & FCU 1-2-2			Level 1 - Open Lobby
				FCU 1-2-3 to FCU 1-2-5			Level 1 - Open Lobby
Daikin	CU 2-2			FCU 2-2-1			Level 2 - Server Room
				FCU 2-2-2			Level 2 - Walkway
				FCU 2-2-3			Level 2 - Classroom 2B
Daikin	CU 2-3			FCU 2-3-1			Level 2 - Classroom 1
				FCU 2-3-2			Level 2 - Classroom 2A
				FCU 2-3-3			Level 2 - Corridor
				FCU 2-3-4			Level 2 - Server Room
Daikin	AP CU 2-1			APU 2-1			Level 2 - Auditorium
Daikin	CU 2-4			FCU 2-4			Level 2 - Auditorium
				FCU 2-5			Level 2 - Auditorium
				FCU 2-6			Level 2 - Auditorium
				FCU 2-7			Level 2 - Auditorium
Daikin	CU 2-8			FCU 2-8			Level 2 - Event Hall
				FCU 2-9			Level 2 - Event Hall
				FCU 2-10			Level 2 - Event Hall
				FCU 2-11			Level 2 - Event Hall
Daikin	CU 3-1			FCU 3-1-1			Level 3 - Room 2
				FCU 3-1-2			Level 3 - Wheelchair Parking
				FCU 3-1-3			Level 3 - Room 6
				FCU 3-1-4			Level 3 - Corridor
				FCU 3-1-5 & FCU 3-1-6			Level 3 - Treatment Area
Daikin	CU 3-2			FCU 3-2-1			Level 3 - Room 1
				FCU 3-2-2			Level 3 - Staff Rest Area
				FCU 3-2-3			Level 3 - Consultation 1
				FCU 3-2-4 & FCU 3-2-5			Level 3 - Treatment Area
Daikin	CU 3-3			FCU 3-3-1			Level 3 - Room 5
				FCU 3-3-2			Level 3 - Room 4
				FCU 3-3-3			Level 3 - Store
				FCU 3-3-4			Level 3 - Water Treatment Room
				FCU 3-3-5 & FCU 3-3-6			Level 3 - Treatment Area
Daikin	CU 3-4			FCU 3-4-1			Level 3 - Room 3
				FCU 3-4-2			Level 3 - MPR
				FCU 3-4-3			Level 3 - Water Treatment Room
				FCU 3-4-4 & FCU 3-4-5			Level 3 - Treatment Area

Daikin	CU 3-5		FCU 3-5-1 FCU 3-5-2 FCU 3-5-3 FCU 3-5-4		Level 3 - Cleaning Room Level 3 - Wheelchair Level 3 - Consultation 2 Level 3 - Lift Lobby
	AP CU 3-1		APU 3-1		Level 3 - Event Hall
	AP CU 3-2		APU 3-2		Level 3 - Treatment Area
Daikin	CU-5-182	RXQ10 + RXQ10	FCU N4-1A FCU N4-1B FCU N4-1C FCU N4-1D		Level 4 - Lift Lobby Level 4 - Pantry Level 4 - Discussion / Meeting Area Level 4 - Meeting Room 4A
			FCU N4-2A FCU N4-2B FCU N4-2C FCU N4-2D		Level 4 - Director Room Level 4 - Director Room Level 4 - Meeting Room 4B Level 4 - Comcare
			FCU N4-3A FCU N4-3B FCU N4-3C FCU N4-3D FCU N4-3E		Level 4 - Nursing Services Level 4 - Nursing Services Level 4 - Comcare Level 4 - Comcare Level 4 - Director Room
Daikin	CU-5-182	RXQ10 + RXQ10	FCU N4-4A FCU N4-4B FCU N4-4C		Level 4 - Comcare Level 4 - Comcare Level 4 - Comcare
			FCU-L5-BUILDING FCU-L5-BIOMDCENG FCU-L5-IT-1 FCU-L5-IT-2 FCU-L5-PURCHASING FCU-L5-SUPRTSERV-1 FCU-L5-SUPRTSERV-2	FXMQ12SPAVE FXMQ12SPAVE FXMQ20PAVE FXMQ80PAVE FXMQ12SPAVE FXMQ32PAVE FXMQ32PAVE	Level 5 - Building Level 5 - Biomedical Engineering Level 5 - IT Level 5 - IT Level 5 - Purchasing Level 5 - Support Services Level 5 - Support Services
			FCU-L5-IT-3 FCU-L5-IT-4 FCU-L5-MDCSERV-1 FCU-L5-DOCRM FCU-L5-LOGISTDRIV/WAIT FCU-L5-MDCSERV-2 FCU-L5-MDCSERV-3 FCU-L5-MDCSERV-4 FCU-L5-DOCOFFICE FCU-L5-LOGISTWA	FXMQ80PAVE FXMQ80PAVE FXMQ12SPAVE FXMQ50PAVE FXMQ80PAVE FXMQ20PAVE FXMQ28PAVE FXMQ25PAVE FXMQ25PAVE FXMQ63PAVE	Level 5 - IT Level 5 - IT Level 5 - Medical Services Level 5 - Doctor's Room Level 5 - Logistics Drivers / Waiting Area Level 5 - Medical Services Level 5 - Medical Services Level 5 - Medical Services Level 5 - Doctor's Office Level 5 - Logistics Work Area
Daikin	CU-7-5	RXQ16AMYM	FCU-E5-5A FCU-E6-5B FCU-E7-5C	FXMQ80PAVE FXMQ80PAVE FXMQ80PAVE	Level 5 - Lift Lobby Level 6 - Lift Lobby Level 7 - Lift Lobby
Daikin	CU-6-384	RXQ10 + RXQ10	FCU-E6-8 FCU-N6-4 FCU-N6-5 FCU-N6-6 FCU-E6-9 FCU-E6-7 FCU-N6-2 FCU-N6-3 FCU-N6-1 FCU-L-CCO-3	FXMQ12SPAVE FXMQ40PAVE FXMQ40PAVE FXMQ63PAVE FXMQ80PAVE FXMQ20PAVE FXMQ32PAVE FXMQ25PAVE FXMQ25PAVE FXMQ80PAVE	Level 6 - Pantry Level 6 - Meeting Room 1 Level 6 - Meeting Room 2 Level 6 - Meeting Room 3 Level 6 - Reception Lobby Level 6 - Nursing Room Level 6 - Central Meeting Room Level 6 - Doctor Room 2 Level 6 - Doctor Room 1 Level 6 - Office Area
			FCU-L-CCO-2 FCU-L-CCO-1 FCU-L6-DVM-2 FCU-L6-DVM-3 FCU-L6-DVM-1	FXMQ80PAVE FXMQ80PAVE FXMQ80PAVE FXMQ12SPAVE FXMQ12SPAVE	Level 6 - Office Area Level 6 - Office Area Level 6 - Office Area Level 6 - Office Area Level 6 - Office Area
	CU-LAN-1&2	RKS50GVMG	FCU-LAN-1&2	FTKS50GVMG	Level 6 - Lan Room
Daikin	CU-7-182	RXQ10 + RXQ10	FCU-7-2-6 FCU-7-2-7 FCU-7-2-8 FCU-7-2-10 FCU-7-2-11 FCU-7-2-2 FCU-7-2-5 FCU-7-2-4 FCU-7-2-3 FCU-7-2-1 FCU-7-2-9	FXMQ25PAVE FXMQ25PAVE FXMQ40PAVE FXMQ25PAVE FXMQ25PAVE FXMQ25PAVE FXMQ32PAVE FXMQ80PAVE FXMQ80PAVE FXMQ80PAVE FXMQ80PAVE	Level 7 - Director Room 2 Level 7 - Director Room 1 Level 7 - Finance Room Level 7 - Director Room 3 Level 7 - Director Room 4 Level 7 - Payroll Level 7 - Manager Area Level 7 - Manager Area Level 7 - Office Area Level 7 - Office Area Level 7 - Storage
			FCU-7-1-1 FCU-7-1-2 FCU-7-1-3 FCU-7-1-4 FCU-7-1-6 FCU-7-1-7 FCU-E7-9	FXMQ25PAVE FXMQ25PAVE FXMQ12SPAVE FXMQ20PAVE FXMQ80PAVE FXMQ12SPAVE FXMQ12SPAVE	Level 7 - CEO Room Level 7 - Auditor & Interview Room Level 7 - Office Area Level 7 - Auditor & Interview Room Level 7 - Meeting Room (M) Level 7 - Meeting Room (L) Level 7 - Reception Office
	CU-7-5	RXMQ4AVE	FCU-N7-10 FCU-N6-7	FXMQ50PAVE FXMQ50PAVE	Level 7 - Meeting Room (L) Level 6 - Pantry
Daikin	CU LL		FCU LL-1 FCU LL-2 FCU LL-3 FCU LL-4 FCU LL-5		Level 8 - Lift Lobby Level 9 - Lift Lobby Level 10 - Lift Lobby Level 11 - Lift Lobby Level 12 - Lift Lobby



Mechanical Ventilation Fan List (19 nos.)					
Fan No	Model	Air Flow	Control	Location	Remark
EAF 1-1		510		Level 1 - FCC	
EAF 1-2		560		Level 1 - Female Toilet	
EAF 1-3		600		Level 1 - Male Toilet	
EAF 1-4		170		Level 1 - Handicap Toilet	
EAF 2-1		1380		Level 2 - Male Toilet	
EAF 2-2		180		Level 2 - Handicap Toilet	
EAF 2-3		1350		Level 2 - Female Toilet	
EAF 2-4		280		Level 2 - PABX	
EAF 2-5		380		Level 2 - Store	
EAF 2-6		260		Level 2 - Pantry	
EAF 3-1		630		Level 3 - IT/AV Room	
EAF 3-2		660		Level 3 - Female Toilet	
EAF 3-3		190		Level 3 - Handicap Toilet	
EAF 3-4		930		Level 3 - Male Toilet	
EAF 3-5		470		Level 3 - Wash Bay	
EAF T-1		190		Level 8 to 12 - Female Toilet	
EAF T-2		205		Level 8 to 12 - Handicap Toilet	
EAF T-3		770		Level 8 to 12 - Male Toilet	
FAF 1-1		470		Level 1 - FCC	

29. NKF Mun Hean Medical Store (2 nos.)							
Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
2 Sets Of Single Split (Daikin) Wall Mounted (12,000btu) R35 + FT35 (Wireless Remote)							

30.109 Pertoneal Dialysis Centre (12 nos.)							
Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	4MKS80	E002507	FCU 1-1	FFQ35B	E010683	Waiting Area
				FCU 1-2	FFQ50B	E015558	Waiting Area
Daikin	CU 2	3MKS71	E006535	FCU 2-1	FFQ50B	E015553	Waiting Area
				FCU 2-2	FFQ25B	E005938	Waiting Area
Daikin	CU 3	3MKS50	E016802	FCU 3-1	FTKS25	E134994	Room 1
				FCU 3-2	FTKS25	E134992	
Daikin	CU 4	4MKS80	E002578	FCU 4-1	FTKS25	E134975	Room 3
				FCU 4-2	FTKS25	E134993	Room 4
				FCU 4-3	FFQ35B	E010496	Consultation Room
Daikin	CU 5	4MKS80	E003198	FCU 5-1	FFQ35B	E010685	Area 2
				FCU 5-2	FFQ50B	E015555	Area 2
Daikin	CU 6	RZR50LVVM	E002505	FCU 6-1	FCQ50L	E004633	Area 2

31. 225 Toa Payoh DC (33 nos.)							
Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU V1	RSUQ7AYMG	E000193	FCU 1-1	FXFSQ63AVM	E002414	Treatment Area
				FCU 1-2	FXFSQ63AVM	E002430	Treatment Area
				FCU 1-3	FXFQ25AVM	E008466	Clean Utilities 2
				FCU 1-4	FXAQ256M	E023422	BME Room
Daikin	CU V2	RSUQ8AYMG	E000275	FCU 2-1	FXFSQ63AVM	E002415	Treatment Area
				FCU 2-2	FXFSQ63AVM	E002427	Treatment Area
				FCU 2-3	FXFSQ50AVM	E002028	Water Treatment Room
				FCU 2-4	FXFSQ40AVM	E001031	Nurse Counter
Daikin	CU V3	RSUQ7AYMG	E016530	FCU 3-1	FXAQ25AVM	E023425	Nurse Manager's Room
				FCU 3-2	FXFSQ63AVM	E002559	Treatment Area
				FCU 3-3	FXFSQ63AVM	E002416	Treatment Area
				FCU 3-4	FXAQ25AVM	E008465	Clean Utility 2
Daikin	CU V4	RSUQ9AYMG	E000277	FCU 4-1	FXFSQ63AVM	E002612	Treatment Area
				FCU 4-2	FXFSQ63AVM	E002417	Treatment Area
				FCU 4-3	FXFQ32AVM	E010535	Corridor
				FCU 4-4	FXFQ30AVM	E020730	Water Treatment Room
Daikin	CU V5	RSUQ7AYMG	E000210	FCU 5-1	FXFQ25AVM	E008755	AV IT Equipment Room
				FCU 5-2	FXFQ25AVM	E008468	Staff Rest Room
				FCU 5-3	FXFSQ63AVM	E002506	Treatment Area
				FCU 5-4	FXFSQ63AVM	E002434	Treatment Area
Daikin	CU V6	RSUQ7AYMG	E000209	FCU 6-1	FXFQ25AVM	E008756	Single Room
				FCU 6-2	FXFQ25AVM	E008764	Ante Room
				FCU 6-3	FXFQ25AVM	E008754	Clean Utilities 1
				FCU 6-4	FXFSQ63AVM	E002503	Treatment Area
				FCU 6-5	FXFQ25AVM	E008753	Consultation Room
Daikin	CU V7	RSUQ7AYMG	E000277	FCU 7-1	FXFQ25AVM	E008757	Staff Rest Room
				FCU 7-2	FXFQ32AVM	E010705	Waiting Area
				FCU 7-3	FXFSQ63AVM	E002507	Treatment Area
				FCU 7-4	FXFSQ63AVM	E002435	Treatment Area
Daikin	CU V8	RSUQ9AYMG	E000298	FCU 8-1	FXFSQ25AVM	E002431	Treatment Area
				FCU 8-2	FXFSQ63AVM	E002432	Treatment Area
				FCU 8-3	FXFSQ50AVM	E001893	Nurse Counter
				FCU 8-4	FXFQ25AVM	E008752	Clean Utilities 1

Mechanical Ventilation Fan List (13 nos.)					
Fan No	Model	Air Flow	Control	Location	Remark
TEAF-1-1	CIL 160	200		Handicap Toilet 2	
EAF-1-1	CIL 125	150		Wash Area	
EAF-1-2	CIL 100	100		Janitor Room	
FAF-1-1	CIL 200	400		Nurse Manager's Room/Nurse Counter/Partial Treatment Area A	
FAF-1-2	CIL 200	350		Clean Utilities 2/RO Plant Rpgm/Interior Corridor/BME Room/Partial Treatment Area A	
TEAF-1-2	CIL 125	150		Staff Toilet	
EAF-1-3	CIL 100	100		Changing Room	
TEAF-1-3	CIL 160	200		Handicap Toilet 1	
EAF-1-4	CIL 125	150		Wash Area (R)	
EAF-1-5	CIL 100	100		Janitor Room (R)	
FAF-1-3	CIL 200	400		Staff Rest Room/AV IT Equipment Room/Waiting Area/Consultation Room/Nurse Counter/Partial Treatment Area B	
FAF-1-4	CIL 200	350		Clean Utilities 1/Partial Treatment Area B	
FAF-1-5	CIL 125	100		Ante Room/Single Room	

32. Toa Payoh West CC DC (21 nos.)							
Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXMQ8AY1	E001550	FCU 1-1	FXFQ32A	E006517	Consultation Room
				FCU 1-2	FXFQ25A	E004542	Waiting Area
				FCU 1-3	FXFSQ63A	E001221	Treatment Area
				FCU 1-4	FXFSQ63A	E001224	Treatment Area
Daikin	CU 2	RXMQ8AY1	E001542	FCU 2-1	FXFQ50A	E010397	Waiting Area
				FCU 2-2	FXZQ32A	E004547	Clean Utility Room 1
				FCU 2-3	FXFSQ32A	E000431	Nursing Room
				FCU 2-4	FXFSQ63A	E001225	Treatment Area
				FCU 2-5	FXFQ32A	E006494	Staff Rest Room
Daikin	CU 3	RXMQ8AY1	E001800	FCU 3-1	FXFSQ40A	E000560	Corridor
				FCU 3-2	FXFSQ63A	E001223	Treatment Area
				FCU 3-3	FXFSQ63A	E001440	Treatment Area
Daikin	CU 4	RXMQ8AY1	E001541	FCU 4-1	FXFSQ63A	E001460	Treatment Area
				FCU 4-2	FXFQ25A	E004544	Switch Room
				FCU 4-3	FXFQ50A	E010394	Water Treatment Room
				FCU 4-4	FXFQ25A	E004546	BME Room
Daikin	CU 5	RXMQ8AY1	E001517	FCU 5-1	FXFQ32A	E006519	Staff Rest Room
				FCU 5-2	FXFSQ40A	E000562	Corridor
				FCU 5-3	FXFQ30A	E010392	Water Treatment Room
				FCU 5-4	FXFQ40A	E005106	Clean Utility Room 2
				FCU 5-5	FXFQ40A	E004703	Clean Utility Room 2



33. 311 Ubi DC (22 nos.)							
Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXMQ6AVE	E001376	FCU 1-1	FXFQ25LUV1	E007242	Staff Rest Room
				FCU 1-2	FXFQ25LUV1	E006570	Consultation Room
				FCU 1-3	FXFQ25LUV1	E006571	TV/Reading Area
				FCU 1-4	FXFQ63LUV1	E023653	Exercise Area
Daikin	CU 2	RXMQ6AVE	E001367	FCU 2-1	FXFQ25LUV1	E006584	Staff Rest Room
				FCU 2-2	FXFQ25LUV1	E006668	TV/Reading Area
				FCU 2-3	FXFQ25LUV1	E006583	
				FCU 2-4	FXFQ63LUV1	E023679	Exercise Area
Daikin	CU 3	RXMQ5AVE	E004007	FCU 3-1	FXFQ32LUV1	E009295	BME Room
				FCU 3-2	FXFQ25LUV1	E006573	Water Treatment Room
				FCU 3-3	FXAQ20PVE	E027895	Clean Utilities Room
Daikin	CU 4	RXMQ5AVE	E001750	FCU 4-1	FXFQ25LUV1	E006578	Water Treatment Room
				FCU 4-2	FXSQ50PVE	E001949	Nurse Counter
				FCU 4-3	FXFQ50LUV1	E016345	Treatment Area (Station 14)
Daikin	CU 5	RXMQ8AY1	E000602	FCU 5-1	FXFQ50LUV1	E016343	Treatment Area (Station 13)
				FCU 5-2	FXFQ50LUV1	E016258	Treatment Area (Station 5)
				FCU 5-3	FXFQ50LUV1	E016257	Treatment Area (Station 8)
				FCU 5-4	FXFQ50LUV1	E016346	Treatment Area (Station 10)
Daikin	CU 6	RXMQ4AVE	E004008	FCU 6-1	FXFQ32LUV1	E009297	Trolley Bay
				FCU 6-2	FXFQ25LUV1	E006586	
				FCU 6-3	FXAQ20PVE	E027894	Observation Room
				FCU 6-4	FXAQ20PVE	E027906	Single Room

34. 19 Upper Boon Keng DC (28 nos.)							
Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1A	RXMQ6AVE	E004054	FCU 1A-1	FXFQ50AVM	E005961	Sponsor Office (reception)
				FCU 1A-2	FXFQ50AVM	E005661	Sponsor Office (office space)
				FCU 1A-3	FXFQ50AVM	E006131	Sponsor Office (staff corner)
Daikin	CU 2A	RZR71LVVMG	E008906	FCU 2A	FCQ71LUV1	E027862	Staff Rest Room
Daikin	CU 3A	RZFC3SEV1G	E000305	FCU 3A	FFFC35AVMG	E000349	Consultation Room
Daikin	CU 4A	3MKS71FSG	E030944	FCU 4A-1	FFQ35BV1B	E016619	Corrdior
				FCU 4A-2	FFQ35BV1B	E017085	Corrdior
Daikin	CU 5A	MKS65TVMG	E001170	FCU 5A-1	CTKS25TVMG	8015451T	BME Room
				FCU 5A-2	CTKS25TVMG	8015432T	Water Treatment Room
				FCU 5A-3	CTKS25TVMG	8015429T	Clean Utilities Room
Daikin	CU 5A-1	RKS50GVMG	E024835	FCU 5A-4	FTKS50GVMG	E023214	Water Treatment Room
Daikin	CU 1B	RZR50LVVM	E008608	FCU 1B	FCQ50LUV1	E008086	Waiting Area
Daikin	CU 2B	RZR50LVVMG	E008608	FCU 2B	FCQ50LUV1	E008729	Treatment Area (Station 18)
Daikin	CU 3B	RZR50LVVMG	E009048	FCU 3B	FCQ50LUV1	E008754	Treatment Area (Station 1)
Daikin	CU 4B	RZR71LVVMG	E011758	FCU 4B	FCQ71LUV1	E030677	Treatment Area (Station 16)
Daikin	CU 5B	RZR71LVVMG	E007730	FCU 5B	FCQ71LUV1	E027707	Treatment Area (Station 2 & 3)
Daikin	CU 6B	RZF50CV1G	E000857	FCU 6B	FCF50CVMG	E000907	Treatment Area (Station 14)
Daikin	CU 7B	RZR71LVVMG	E007518	FCU 7B	FCQ71LUV1	E027363	Treatment Area (Station 6)
Daikin	CU 8B	RZR71LVVMG	E010946	FCU 8B	FCQ71LUV1	E029789	Clean Utilities 2
Daikin	CU 9B	RZR50LVVM	E005509	FCU 9B	FCQ50LUV1	E006420	Treatment Area (Station 11)
Daikin	CU 10B	RZR71LVVMG	E007418	FCU 10B	FCQ71LUV1	E027337	Tratemet Area (Station 8)
Daikin	CU 11B	RZR50LVVM	E008382	FCU 11B	FCQ50LUV1	E008364	Treatment Area (near Clean Utilities 2)
Daikin	CU 13B	RZR50LVVM	E008315	FCU 13B	FCQ50LUV1	E008345	Nurse Counter
Mitsubishi	CU 14B	MKS650VMG	E009685	FCU14B-1	CTKS25QVM	E043750	Nurse Manager's Room
				FCU14B-2	CTKS25QVM	E043423	Clean Utilities Room
Daikin	CU 15B	RKM25XVMG	E000413	FCU 15B	FTKM25XVMG	E001118	Treatment Area (Station 10)
Daikin	CU 16B	4MKS80FSG	E016510	FCU 16B	FFQ50BV1B	E24036	Treatment Area (Station 5)
Daikin	CU 18B	RKM50PVMG	E003190	FCU 18B	FTKM50PVM	E005736	Clean Utilities 3

ACMV List for NKF Dialysis Centres

35. 274 Bangkit DC (15 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RZR71LVVMG	E001817	FCU 1	FCQ71LUV1	E022347	Treatment Area (Station 10)
Daikin	CU 2	RZR71LVVM	E002613	FCU 2	FCQ71LUV1	E008524	Treatment Area (Station 12 & 13)
Daikin	CU 3	RZF71CV1G	E003585	FCU 3	FCF71CVMG	E003468	Treatment Area (Station 8 & 9)
Daikin	CU 4	RZR60LVVM	E004960	FCU 4	FCQ60LUV1	E005851	Clean Utilities 3
Daikin	CU 5	RZR71LVVMG	E015403	FCU 5	FCQ71LUV1	E033555	Treatment Area (Station 15 &16)
Daikin	CU 6	RZR50LVVM	E005743	FCU 6	FCQ50LUV1	E006310	Waiting Area
Daikin	CU 7	RZR71LVVMG	E008623	FCU 7	FCQ71LUV1	E028058	Treatment Area (Station 5 & 6)
Daikin	CU 8	RZR71LVVMG	E008384	FCU 8	FCQ71LUV1	E028218	Treatment Area (Station 1 to 3)
Daikin	CU 9	RKS35GVMG	E028341	FCU 9	FTKS35DVM	E093640	Consultation Room
Daikin	CU 10	RKS35GVMG	E030237	FCU 10	FTKS35DVM	E091648	Nurse Manager's Room
Daikin	CU 11	RZR50LVVM	E009019	FCU 11	FCQ50LUV1	E008578	Staff Rest Room
Daikin	CU 12	RZF50CV1G	E000442	FCU 12	FCF50CVMG	E000860	Waiting Area (Staff Area)
Daikin	CU 13	RZR50LVVM	E010113	FCU 13	FCQ50LUV1	E009707	Water Treatment Room
Daikin	CU 13A	R50GV1G	E003583	FCU 13A	FT50GV1G	E003575	Water Treatment Room
Daikin	CU 14	RZR50LVVM	E010108	FCU 14	FCQ50LUV1	E009503	BME Room

36. 275 Bangkit DC (27 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1-1	RXMQ4P	E003842	FCU 1-1/1 FCU 1-1/2 FCU 1-1/3 FCU 1-1/4	FXFQ25L FXFQ32L FXFQ25L FXFQ32L	E004278 E002453 E004276 E002442	Waiting Area Outside Clean Utilities 1 Clean Utilities 1 Treatement Area (Station 14 & 15)
Daikin	CU 1-2	RXMQ5P	E004238	FCU 1-2/1 FCU 1-2/2 FCU 1-2/3 FCU 1-2/4	FXFQ25L FXFQ32L FXFQ32L FXFQ32L	E004315 E005139 E005131 E005128	Waiting Area Treatment Area (Station 12 & 13) Treatment Area (Station 10 & 11) Treatment Area (Station 9)
Daikin	CU 1-3	3MKS71	E036869	FCU 1-3/1 FCU 1-3/2	FFQ35B FFQ35B	E009447 E009527	Treatment Area (Station 1 & 2) Treatment Area (Station 3)
Daikin	CU 1-4	3MKS71	E035541	FCU 1-4/1 FCU 1-4/2	FFQ35B FFQ35B	E009675 E009734	Treatment Area (Station 4) Nurse Counter (c/cassette)
Daikin	CU 1-5	3MKS71	E036987	FCU 1-5/1 FCU 1-5/2	FFQ35B FFQ35B	E009735 E009526	Treatment Area (Station 5 & 6) Treatment Area (Station 7 & 8)
Daikin	CU 1-6	3MKS50	E015485	FCU 1-6/1 FCU 1-6/2	FFQ25B FFQ25B	E005609 E005605	Clean Utilities 3 Clean Utilities 2
Daikin	CU 2-1	RXMQ4P	E003677	FCU 2-1/1 FCU 2-1/2 FCU 2-1/3	FXFQ25L FXFQ32L FXFQ32L	E004264 E005129 E002440	Outside Nursge Manager's Room Consultation Room Staff Rest Room
Daikin	CU 2-2	RXMQ4P	E003844	FCU 2-2/1 FCU 2-2/2 FCU 2-2/3 FCU 2-2/4	FXFQ32L FXFQ25L FXFQ25L FXFQ25L	E005132 E004280 E004337 E004274	Staff Rest Room Nurse Manager's Room Staff Lockers Area Corridor to pantry
Daikin	CU 2-3	RZR50LVVM	E001829	FCU 2-3/1	FCQ50L	E003345	Water Treatment Room
Daikin	CU 2-4	RZR50LVVM	E001823	FCU 2-4/1	FCQ50L	E003341	Water Treatment Room
Daikin	CU 2-5	3MKS50	E015614	FCU 2-5/1 FCU 2-5/2	FFQ25B FFQ25B	E005604 E005603	BME Room External Storeroom

37. 113A Bukit Batok DC (22 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU V1	RXUQ10AYM	E000735	FCU1-1 FCU1-2 FCU1-3 FCU1-4	FXFQ40BVM FXFSQ80AVM FXFSQ80AVM FXFQ40AVM	E000135 E002714 E002718 E014056	Consultation Room Station 1 Station 28 Waiting Area
Daikin	CU V2	RXUQ10AYM	E000738	FCU2-1 FCU2-2 FCU2-3 FCU2-4	FXFSQ80AVM FXFQ40AVM FXFSQ80AVM FXFSQ80AVM	E001151 E011895 E002713 E002623	Nurse Counter (Medical Fridge) Corridor (Outside Toliets) Station 18 Station 3 & 4
Daikin	CU V3	RXUQ12AYM	E000507	FCU3-1 FCU3-2 FCU3-3 FCU3-4	FXFQ63AVM FXFSQ80AVM FXFSQ80AVM FXFQ40AVM	E041461 E002667 E002624 E011897	Clean Utility 2 Station 34 & 35 Station 23 Staff Rest Room
Daikin	CU V4	RXUQ10AYM	E000732	FCU4-1 FCU4-2 FCU4-3 FCU4-4 FCU4-5	FXFSQ80AVM FXFSQ80AVM FXFSQ40AVM FXZQ40BVM FXZQ40BVM	E002661 E027858 E001167 E000134 E000137	Treatment Area (Station 11) Treatment Arae (Station 14) Water Treatment Room Corridor (Outside AV/Equip Room) Corridor (Outisde Janitor Room)
Daikin	CU V5	RXUQ12AYM	E000501	FCU 5-1 FCU 5-2 FCU 5-3 FCU 5-4 FCU 5-5 FCU 5-6	FXFQ40AVM FXFQ40AVM FXFSQ80AVM FXFQ100AVM FXFSQ40AVM FXFQ25AVM	E014062 E014053 E014057 E038581 E014060 E011228	Standby HD Machines Staff Rest Room Nurse Counter (Near Weighing Scale) Clean Utilities 1 Water Treatment Room Multi Purpose Room

38. 128 Bukit Merah DC (22 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RZF50CV1G	E000446	FCU 1-1	FCF50CVMG	E000343	Exit Door Aea
Daikin	CU 2	3MKS71	E036237	FCU 2-1 FCU 2-2	FFQ25B FFQ50B	E004899 E013686	Clean Utilities 1 Corridor
Daikin	CU 3	RXMQ5P	E003823	FCU 3-1 FCU 3-2	FXFQ63L FXFQ50L	E014950 E009007	Treatment Area (Station 8) Treatment Area (Station 2)
Daikin	CU 4	RXMQ5P	E003915	FCU 4-1 FCU 4-2	FXFQ63L FXFQ50L	E014930 E009004	Treatment Area (Station 5) Nurse Counter
Daikin	CU 5	RKS35A	E001682	FCU 5-1	FFQ35B	E008554	Waiting Area
Daikin	CU 6	RKS35A	E001679	FCU 6-1	FFQ35B	E008446	Waiting Area
Daikin	CU 7	RKS35A	E001754	FCU 7-1	FFQ35B	E008443	BME Room
Daikin	CU 8	RKS50	E025236	FCU 8-1	FTKS50	E023247	Water Treatment Room
Daikin	CU 9	RKS50	E025292	FCU 9-1	FTKS50	E034100	Water Treatment Room
Daikin	CU 10	5MKS100	E005865	FCU 10-1 FCU 10-2	FTKS50F FTKS35	E023068 E098411	Consultation Room Nurse Manager's Room
Daikin	CU 11	3MKS71	E036177	FCU 11-1 FCU 11-2	FTKS25 FFQ50B	E057486 E013690	Locker Staff Rest Room
Daikin	CU 12	3MKS71	E036246	FCU 12-1 FCU 12-2	FFQ35B FFQ35B	E008451 E008521	Clean Utilities 2 Waiting Room
Daikin	CU 13	RXMQ4AAVEG	E00456	FCU 13-1 FCU 13-2	FXFQ50AVM FXFQ50AVM	E018879 E017012	Treatment Area Treatment Area
Daikin	CU 14	5MKS100	E007576	FCU 14-1 FCU 14-2	FFQ50B FFQ50B	E011028 E011029	Treatment Area (Station 10) Treatment Area (Station 13)



39. 326 Clementi DC (26 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXMQ8AY1	E001713	FCU 1-1	FXFSQ63AVM	E000481	Treatment Area
				FCU 1-2	FXFSQ63AVM	E000534	Treatment Area
				FCU 1-3	FXFSQ63AVM	E000535	Treatment Area
Daikin	CU 2	RXMQ8AY1	E001708	FCU 2-1	FXFSQ63AVM	E000678	Treatment Area
				FCU 2-2	FXFSQ63AVM	E000677	Treatment Area
				FCU 2-3	FXFSQ63AVM	E000562	Treatment Area
Daikin	CU 3	RXMQ10AYM	E001086	FCU 3-1	FXFSQ63AVM	E000561	Treatment Area
				FCU 3-2	FXFSQ63AVM	E000480	Treatment Area
				FCU 3-3	FXFSQ63AVM	E000675	Treatment Area
				FCU 3-4	FXFQ25AVM	E002169	Store Room
				FCU 3-5	FXFQ25AVM	E044176	DB Room
Daikin	CU 4	RXMQ8AY1	E001709	FCU 4-1	FXFSQ63AVM	E000560	Treatment Area
				FCU 4-2	FXFSQ63AVM	E000563	Treatment Area
				FCU 4-3	FXFQ25AVM	E002084	Open Passage Way
				FCU 4-4	FXFQ25AVM	E002166	Store Room 2
Daikin	CU 5	RXMQ8AY1	E001712	FCU 5-1	FXFQ25AVM	E002162	Open Passage Way
				FCU 5-2	FXFQ32AVM	E003273	Staff Rest Room
				FCU 5-3	FXFQ40AVM	E003305	Waiting Area
				FCU 5-4	FXFQ25AVM	E002163	Doctor Room
				FCU 5-5	FXFQ25AVM	E002085	Nurse Manager Room
				FCU 5-6	FXFQ50AVM	E006442	Water Treatment Room
Daikin	CU 6	RXMQ6AYE	E003415	FCU 6-2	FXFQ32AVM	E003274	Staff Rest Room
				FCU 6-3	FXFQ25AVM	E002168	BME Room
				FCU 6-5	FXFQ25AVM	E002165	Corridor
				FCU 6-1	FXFQ32AVM	E003401	Store Room 1
				FCU 6-4	FXFQ50AVM	E005755	Water Treatment Room

326 Clementi Mechanical Ventilation Fan List (09 nos.)

Fan No	Model	Air Flow	Control	Location	Remark
EAF-1	FM160	250		Wash Room	
EAF-2	FM160	145		Handicap 2	
EAF-3	FM160	145		Handicap 1	
EAF-4	FM161				
EAF-4	FM160	210		Toilet	
FAF-1	FM315	440		Treatment Area	Interlock with fcus
FAF-2	FM315				
FAF-2	FM315	440		Treatment Area	
FAF-3	FM200	300		Store 2,3, Switch RM,	
FAF-4	FM200	350		Waiting, Corridor, Staff	
FAF-5	FM160	200		Store 1,Nurse MGR RM,	

40. Integrated Renal Centre (143 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
<b>Level 1 Common Area &amp; Dialysis Centre</b>							
Daikin	CU V1-1	RXQ12TAYM	E002972	VFCU/1-1A	FXAQ25P	E019962	Wash Area
				VFCU/1-1B	FXFQ80S	C001766	Treatment Area
				VFCU/1-1C	FXFQ40L	E006614	BME Room
				VFCU/1-1D	FXFQ80S	C001778	Treatment Area
				VFCU/1-1E	FXFQ80S	C001765	Treatment Area
Daikin	CU V1-2	RXQ12TAYM	E002981	VFCU/1-2A	FXFQ80S	C001779	Treatment Area
				VFCU/1-2B	FXFQ40L	E008559	BME Room
				VFCU/1-2C	FXFQ80S	C001757	Treatment Area
				VFCU/1-2D	FXFQ80S	C001769	Treatment Area
Daikin	CU V1-3	RXQ10TAYM	E001701	FCU 1-3A	FXFQ80S	C001777	Treatment Area
				FCU 1-3B	FXFQ80S	C001775	Treatment Area
				FCU 1-3C	FXFQ80S	C001763	Treatment Area
Daikin	CU V1-4	RXQ10TAYM	E001717	FCU 1-4A	FXFQ80S	C001771	Treatment Area
				FCU 1-4B	FXFQ80S	C001776	Treatment Area
				FCU 1-4C	FXFQ80S	C001786	Treatment Area
Daikin	CU V1-5	RXQ8TAYM	E002192	FCU 1-5A	FXFQ40S	C000465	Isolation Area
				FCU 1-5B	FXFQ40S	C000467	Isolation Area
				FCU 1-5C	FXFQ40S	C000469	Isolation Area
				FCU 1-5D	FXFQ40S	C000471	Isolation Area
Daikin	CU V1-6	RXQ22TAS	E003115	FCU 1-6A	FXFQ63S	C002078	Lift Lobby
				FCU 1-6B	FXFQ63S	C002079	Lift Lobby
				FCU 1-6C	FXFQ63S	C002089	Lift Lobby
				FCU 1-6E	FXFQ63L	E026463	Wheelchair Bay
				FCU 1-6F	FXFQ25L	E007950	Nurse Manager's Room 1
				FCU 1-6G	FXFQ25L	E008262	Nurse Manager's Room 2
				FCU 1-6H	FXFQ32L	E009837	Wheelchair Bay
				FCU 1-6I	FXFQ25L	E008263	Outside IT Riser
				FCU 1-6J	FXFQ32L	E010298	Consultation Room
				FCU 1-6K	FXAQ25P	E020085	Pantry
				FCU 1-6L	FXAQ25P	E020088	Store
				FCU 1-6M	FXAQ25P	E019937	Clean Utilities Room
				FCU 1-6N	FXFQ25L	E008463	Outside HT
Daikin	CU V1-7	RXQ10TAYM	E001693	FCU 1-7A	FXFQ63S	C002088	Waiting Area
				FCU 1-7B	FXFQ63S	C002090	Wheelchair Bay
				FCU 1-7C	FXFQ63S	C002080	Waiting Area
				FCU 1-7D	FXFQ63L	C026469	Wheelchair Bay
Daikin	CU V1-8	RXQ14TAYM	E001725	VFCU 1-8A	FXFQ50L	E017194	Centralise Store 2
				VFCU 1-8B	FXFQ50L	E017259	Centralise Store 2
				VFCU 1-8C	FXFQ50L	E017193	Centralise Store 2
				VFCU 1-8D	FXFQ50L	E017195	Centralise Store 2
				VFCU 1-8F	FXFQ63L	E025778	Centralise Store 1
				VFCU 1-8H	FXAQ25P	E020079	FCC Room
				VFCU 1-8I	FXFQ50L	E017758	Corridor Outside New M.T.
Daikin	CU V1-9	RXQ12TAYM	E003097	FCU 1-9A	FXAQ25P	E020151	Pantry
				FCU 1-9B	FXFQ125L	E036307	Gym
				FCU 1-9C	FXFQ125L	E020148	Gym
Daikin	CU V1-10	RXQ16TAYM	E001369	FCU 1-10A	FXFQ125L	E020150	Gym
				FCU 1-10B	FXFQ125L	E020153	Gym
				FCU 1-10C	FXFQ125L	E020152	Gym
Daikin	CU 1-1A	RZR140MYM	E010629	FCU 1-1A	FCQ140KAVEA	E017505	CP1 Water Treatment Room
	CU 1-1B	RZFC140DY1G	E000339	FCU 1-1B	FCFC140DVMG	E000234	CP1 Water Treatment Room
	CU 1-2	RZR50LVVM	E006353	FCU 1-2	FCQ50L	E006684	Ante Room
	CU 1-3	RZR50LVVM	E006326	FCU 1-3	FCQ50L	E006679	Ante Room
	CU 1-4	RKS25	E035631	FCU 1-4	FTKS25	E200765	MDF Room
	CU 1-5	RKS25	E035580	FCU 1-5	FTKS25	E200808	FCC
	CU 1-6	RKS25	E035579	FCU 1-6	FTKS25	E200789	IT Riser
<b>Level 2 Common Area &amp; Dialysis Centre</b>							
Daikin	CU V2-1	RXQ12TAYM	E000754	FCU 2-1A	FXFQ80S	C001746	Treatment Area
				FCU 2-1B	FXFQ80S	C001761	Treatment Area
				FCU 2-1C	FXFQ80S	C001755	Treatment Area
				FCU 2-1D	FXAQ25P	E020091	Wash Area
Daikin	CU V2-2	RXQ14TAYM	E001183	FCU 2-2A	FXFQ80S	C001745	Treatment Area
				FCU 2-2B	FXFQ80S	C001760	Treatment Area

				FCU 2-2C FCU 2-2D	FXFQ80S FXFQ80S	C001756 C001762	Treatment Area Treatment Area
Daikin	CU V2-3	RXQ12TAYM	E002979	FCU 2-3A FCU 2-3B FCU 2-3C FCU 2-3D	FXFQ80S FXFQ80S FXFQ80S FXFQ40L	C001759 C001751 C001754 E009273	Treatment Area Treatment Area Treatment Area CP2 Store
Daikin	CU V2-4	RXQ12TAYM	E002988	FCU 2-4A FCU 2-4B FCU 2-4C FCU 2-4D	FXFQ80S FXFQ80S FXFQ80S FXFQ40L	C001750 C001749 C001758 E009271	Treatment Area Treatment Area Treatment Area CP2 Store
Daikin	CU V2-5	RXQ16TAYM	E001390	FCU 2-5A FCU 2-5B FCU 2-5C FCU 2-5D FCU 2-5E FCU 2-5F FCU 2-5G FCU 2-5H	FXFQ50S FXFQ50S FXFQ50S FXFQ40L FXFQ40L FXFQ40L FXAQ25P FXFQ40L	C000567 C000570 C000564 E009214 E009288 E009177 E034483 E009285	Lift Lobby Lift Lobby Lift Lobby Outside Nurse Manager's Room 1 Staff Pantry Staff Pantry Small Pantry Outside HT
Daikin	CU V2-6	RXQ16TAYM	E001391	FCU 2-6A FCU 2-6B FCU 2-6C FCU 2-6D FCU 2-6E FCU 2-6F FCU 2-6G FCU 2-6H FCU 2-6I FCU 2-6J	FXFQ50S FXFQ50S FXFQ50S FXFQ40L FXFQ40L FXFQ32L FXFQ32L FXFQ40L FXFQ32L FXFQ40L	C000557 C000559 C000569 E009210 E009215 E010398 E010401 E009270 E010453 E009275	Lift Lobby Lift Lobby Lift Lobby Staff Pantry Staff Pantry Nurse Manager's Room 2 Nurse Manager's Room 1 Corridor IT Riser Consultation Room
Daikin	CU 2-1	RKS25	E035630	FCU 2-1	FTKS25	E207649	IT Riser
Daikin		RZR100MVMG	E005380		FCQ100KAVEA FCQ100KAVEA	E023203 E023170	#02-04 #02-04
<b>Level 3 Common Area &amp; Dialysis Centre</b>							
Daikin	CU V3-1	RXQ18TAYM	E001395	FCU 3-1A FCU 3-1B FCU 3-1C FCU 3-1D FCU 3-1E FCU 3-1F FCU 3-1G FCU 3-1H	FXFQ50L FXFQ50L FCFQ80L FCFQ40L FXFQ25L FXFQ50L FXFQ80S FXFQ50L	E018087 E018251 E020892 E009508 E008942 E019252 C001767 E018446	Admin Office Admin Office Treatment Area Admin Office Office Pantry Admin Office Treatment Area Admin Office
Daikin	CU V3-2	RXQ18TAYM	E001614	FCU/3-2A FCU/3-2B FCU/3-2C FCU/3-2D FCU/3-2E FCU/3-2F FCU/3-2G	FXFQ50L FXFQ50L FXFQ50L FXFQ80S FXFQ80S FXFQ80S FXFQ80S	E018253 E018450 E018254 C001753 C001768 C001747 C001743	Admin Office Admin Office Admin Office Treatment Area Treatment Area Treatment Area Treatment Area
Daikin	CU V3-3	RXQ16TAYM	E001634	FCU 3-3A FCU 3-3B FCU 3-3C FCU 3-3D FCU 3-3E	FXFQ80S FXFQ80S FXFQ80S FXFQ80S FXFQ80S	C001774 C001772 C001764 C001744 C001752	Treatment Area Treatment Area Treatment Area Treatment Area Treatment Area
Daikin	CU V3-4	RXQ8TAYM	E002309	FCU 3-4A FCU 3-4B	FXHQ100 FXHQ100	E015996 E017995	IT Server Room IT Server Room
Daikin	CU V3-5	RXQ8TAYM	E002301	FCU 3-5A FCU 3-5B	FXHQ100 FXHQ100	E017999 E017996	IT Server Room IT Server Room
Daikin	CU V3-6	RXQ20TAYM	E001720	FCU 3-6A FCU 3-6B FCU 3-6C FCU 3-6D FCU 3-6E FCU 3-6F FCU 3-6G FCU 3-6H FCU 3-6I FCU 3-6J FCU 3-6K	FXFQ32L FXFQ32L FXFQ32L FXAQ25P FXFQ32L FXFQ63L FXFQ63L FXFQ32L FXFQ50S FXFQ50S FXFQ50S	E010849 E010852 E010846 E033902 E010848 E028044 E028241 E020850 C001369 C001374 C001371	Counselling Room Counselling Room 2 Counselling Room 1 Staff Pantry Outside HT Training Room 1 Training Room 1 Corridor outside New Counselling Rm 1 Lift Lobby Lift Lobby Lift Lobby



Daikin	CU V3-7	RXQ20TAYM	E003109	FCU 3-6L	FXFQ32L	E010847	Outside F.T
				FCU 3-7A	FXFQ32L	E010853	Outside Pantry
				FCU 3-7B	FXFQ32L	E028257	Training Room 1
				FCU 3-7C	FXFQ50S	C001473	Lift Lobby
				FCU 3-7D	FXFQ50S	C001372	Lift Lobby
				FCU 3-7E	FXFQ50S	C001370	Lift Lobby
				FCU 3-7F	FXAQ25P	E033900	Common Area Pantry
				FCU 3-7G	FXFQ32L	E010806	Outside M.T
Daikin	CU V3-9	RXQ6TAYM	E000792	FCU 3-9D	FXFQ50L	E018410	Facilities Office
				FCU 3-9I	FXFQ40L	E009081	Facilities Office
				FCU 3-9J	FXFQ40L	E009620	Facilities Office
Daikin	CU V3-10	RXQ10TAYM	E001741	FCU 3-10A	FXFQ63L	E028258	Training Room 2
				FCU 3-10B	FXFQ63L	E028274	Training Room 2
				FCU 3-10C	FXFQ63L	E027600	Training Room 2
				FCU 3-10D	FXFQ63L	E028279	Training Room 2

41. 1 Ghim Moh DC (26 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	3MKS71FSG	E004145	FCU 1A	FTKS 35 DVM	E106016	Staff Rest Room
				FCU 1B	FTKS 35 DVM	E106023	Staff Rest Room
Daikin	CU 2	RKS50GVMG	E003064	FCU 2A	FTKS 50 GVMG	E003217	Water Treatment Room
Daikin	CU 3	RKS50GVMG	E003052	FCU 3A	FTKS 50 GVMG	E003214	Water Treatment Room
Daikin	CU 4	3MKS71ESG	E009644	FCU 4A	FTKS 25 DVM	E014148	BME Room
				FCU 4B	FTKS 25 DVM	E014143	Waiting area
				FCU 4C	FTKS 25 DVM	E014113	Corridor
Daikin	CU 5	3MKS71ESG	E009650	FCU 5A	FTKS 25 DVM	E 014146	Office 1/Store
				FCU 5B	FTKS 25 DVM	E 014145	Office 2
				FCU 5C	FTKS 25 DVM	E 014100	Consultation Room
Daikin	CU 6	3MKS71FSG	E031910	FCU 6A	FTKS25DVM	E259223	Reprocessing Room
				FCU 6C	FTKS25DVM	E258912	Nurse Manager's Room
Daikin	CU 7	3MKS71ESG	E009634	FCU 7A	FTKS25DVM	E014147	Dialysis Room
				FCU 7B	FTKS25DVM	E014109	Dialysis Room
				FCU 7C	FFQ35B	E001365	Treatment Area
Daikin	CU 8	4MKS80ESG	E005482	FCU 8A	FFQ60B	E001172	Treatment Area
				FCU 8B	FFQ60B	E010465	Treatment Area (Station 18 & 19)
Daikin	CU 9	RXMQ5AAVEG	E000657	FCU 9-1	FXFQ50AVM	E018457	Nurse Counter
				FCU 9-2	FXFQ40AVM	E009329	Treatment Area (Station 15)
				FCU 9-3	FXFQ40AVM	E009325	Treatment Area (Station 12)
Daikin	CU 10	RXMQ5AAVEG	E000637	FCU 10-1	FXFQ50AVM	E017901	Treatment Area (Station 17)
				FCU 10-2	FXFQ40AVM	E009327	Treatment Area (Station 3 & 4)
				FCU 10-3	FXFQ40AVM	E009330	Treatment Area (Station 6)
Daikin	CU 12	4MKS80FSG	E015801	FCU 12A	FFQ 60 B	E001970	Treatment Area (Station 6 to 8)
				FCU 12B	FFQ 60 B	E001971	Treatment Area (Station 9 to10)
Daikin	CU 13	RAR50LVVM	E009417	FCU 13A	FCQ50LUV1	E008949	Waiting Area

42. 240C Jurong East DC (17 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXMQ6AVE	E003153	FCU 1-1 FCU 1-2 FCU 1-3	FXFQ40AVM FXFQ50AVM FXFQ40AVM	E004323 E008295 E004319	Consultation Room Waiting Area 2 Water Treatment Room
Daikin	CU 2	RXMQ6AVM	E004217	FCU 2-1 FCU 2-2 FCU 2-3	FXFQ40AVM FXFQ32AVM FXFQ80AVM	E004319 E005057 E012451	Water Treatment Room BME Staff Rest Room
Daikin	CU 3	RXMQ6AVE	E004219	FCU 3-1 FCU 3-2	FXFQ50AVM FXFSQ100AVM	E008296 E001125	Clean Utilities 1 Treatment Area (beside weighing scale)
Daikin	CU 4	RXMQ8AY1	E001750	FCU 4-1 FCU 4-2	FXFSQ80AVM FXFSQ100AVM	E001131 E000914	Waiting Area 1 Treatment Area (near side exit door)
Daikin	CU 5	RXMQ8AY1	E001751	FCU 5-1 FCU 5-2 FCU 5-3	FXFQ40AVM FXFSQ100AVM FXAQ40PVE	E004359 E000917 E028542	Clean Utilities 2 Treatment Area (Station 13 & 14) Switch Room
Daikin	CU 6	RXMQ8AY1	E001840	FCU 6-1 FCU 6-2	FXFSQ80AVM FXFSQ100AVM	E001134 E000913	Nurse Counter Treatment Area (Station 20)
Daikin	CU 7	RXMQ8AY1	E001749	FCU 7-1 FCU 7-2	FXFSQ100AVM FXFSQ100AVM	E000918 E001132	Treatment Area (Station 18) Treatment Area (Station 11 & 12)

Mechanical Ventilation Fan List (09 nos.)

Fan No	Brand	Model	Air Flow	Location	Remarks
EAF-1	Wall-Prop	VF-AB8R	360	Toilet	
EAF-2	Cil	RS125L	250	HC	
EAF-3	Wall-Prop	VF-AB6R	240	Janitor	
EAF-4	Wall-Prop	VF-AB6R	300	Biohazard	
EAF-5	Cil	RS125L	180	Staff WC	
EAF-6	Cil	RS100L.2CA	80	Staff CR	
EAF-7A	Axial	AND 710/12-	6640	Treatment Area	
EAF-7B	Axial	AND 710/12-	6640	Treatment Area	
EAF-8	Cil	RS160	300	Wash Area	

43. 744 Jurong West DC (14 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1-1	RZF125CV1G	E001173	FCU 1-1	FCF125CVMG	E001311	Treatment Area (Station 1, 2, 13 & 14)
Daikin	CU 1-2	RZR100MVMG	E000683	FCU 1-2	FCQ100KAVEA	E006873	Treatment Area (Nurse Counter, Stat 5 & 6)
Daikin	CU 1-3A CU 1-3B	RZF60CV1G RZR60LVVM	E000209 E007345	FCU 1-3A FCU 1-3B	FCF60CVMG FCQ60LUV1	E000208 E007332	Treatment Area (Station 7 to 9, 16 & 17) Treatment Area (Station 10, 11, 18 to 20)
Daikin	CU 1-4	3MKS71FSG	E029152	FCU 1-4A FCU 1-4B	FTKS 35 DVM FTKS 35 DVM	E178083 E178168	Clean Utilities 2 Next to Station 12
Daikin	CU 1-5	RZF50CV1G	E001202	FCU 1-5	FCF50CVMG	E001232	Clean Utilities 3
Daikin	CU 1-6	RZR100MVMG	E004999	FCU 1-6	FCQ100KAVEA	E013437	Waiting Area
Daikin	CU 1-7	RXMQ4AAVEG	E001377	FCU 1-7A FCU 1-7B	FXFQ63AVM FXAQ25ARVEG	E045119 0000722	Clean Utilities 5 BME Room
Daikin	CU 1-8	3MKS71FSG	E032749	FCU 1-8A FCU 1-8B	FTKS35DVM FFQ50BV1B9	E193582 E023807	Consultation Room Staff Rest Room
Daikin	CU 1-9	RKS50GVMG	E045807	FCU 1-9	FTKS50GVMG	E043775	Water Treatment Room
Daikin	CU 1-10	RKS50GVMG	E049058	FCU 1-10	FTKS50GVMG	E047871	Water Treatment Room

44. 940 Jurong West DC (19 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1A CU 1B	RKS25AVMG RKS35GVMG	E000799 E027378	FCU 1A FCU 1B	FFQ25BV1B FFQ35BV1B	E005380 E008753	Waiting Area (outside patient toilet) Waiting Area (near entrance)
Daikin	CU 2	RXMQ5AAVEG	E001930	FCU 2-1 FCU 2-2	FXFQ63AVM FXFQ50AVM	E039735 E025742	Treatemnt Area (Station 1, 2, 3 & 4) Treatemnt Area (Station 17 & 18)
Daikin	CU 3	RXMQ5PVE	E004059	FCU 3-1 FCU 3-2	FXFQ63LUV1 FXFQ50LUV1	E014593 E015636	Treatment Area (Station 7) Nurse Counter
Daikin	CU 4	RXMQ5PVE	E004062	FCU 4-1 FCU 4-2	FXFQ63LUV1 FXFQ50LUV1	E014595 E008694	Treatment Area (Station 14) Treatment Area (Station 8 to 10)
Daikin	CU 5	3MKS71ESG	E037629	FCU 5-1 FCU 5-2	FTKS25DVM FFQ50BV1B	E078319 E013742	Clean Utilities 3 Clean Utilities 2
Daikin	CU 6	3MKS71ESG	E037625	FCU 6-1 FCU 6-2	FTKS25DVM FFQ35BV1B	E078303 E008747	Clean Utilities 1 Treatment (Station 11 & 12)
Daikin	CU 9	3MKS71ESG	E037627	FCU 9-1 FCU 9-2	FTKS25 FTKS35	E078424 E095387	BME Room Consultation Room
Daikin	CU 10	RXMQ4AAVEG	E000602	FCU 10-1 FCU 10-2	FXFQ32AVM FXFQ50AVM	E013175 E026693	Staff Area Entrance Staff Rest Room
Daikin	CU 11	RKS35GVMG	E027345	FCU 11-1	FTKS35DVM	E095332	Staff Lockers Area
Daikin	CU 12	RKS35GVMG	E027376	FCU 12-1	FTKS35DVM	E095381	Water Treatment Room
Daikin	CU 13	RKS35GVMG	E001716	FCU 13-1	FTKS35DVM	E095367	Water Treatment Room

45. 55 Strathmore DC (26 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXMQ5AVE	E005186	FCU 1-1 FCU 1-2 FCU 1-3	FXAQ25PVE FXFSQ50AVM FXFSQ50AVM	E045207 E000866 E000840	Single Room Treatment Area (Station 15) Treatment Area (Station 12)
Daikin	CU 2	RXMQ5AVE	E005138	FCU 2-1 FCU 2-2 FCU 2-3	FXAQ25PVE FXFSQ50AVM FXFSQ50AVM	E045078 E000841 E000839	Ante Room Treatment Area (Station 16) Treatment Area (Station 21)
Daikin	CU 3	RXMQ5AVE	E005192	FCU 3-1 FCU 3-2 FCU 3-3	FXFSQ40AVM FXFSQ40AVM FXFSQ50AVM	E000536 E000537 E000842	Treatment Area (Station 22) Treatment Area (Station 27) Treatment Area (Station 1)
Daikin	CU 4	RXMQ5AVE	E005173	FCU 4-1 FCU 4-2 FCU 4-3	FXFSQ40AVM FXFSQ40AVM FXFSQ50AVM	E000488 E000349 E0009594	Treatment Area (Station 7) Treatment Area (Station 3) Nurse Station
Daikin	CU 5	RXMQ5AVE	E005093	FCU 5-1 FCU 5-2 FCU 5-3 FCU 5-4	FXFQ25AVM FXFQ25AVM FXFQ40AVM FXFQ40AVM	E003959 E003715 E001038 E005064	Treatment Area (weighing scale) Consultation Room Waiting Area Waiting Area
Daikin	CU 6	RXMQ5AVE	E005087	FCU 6-1 FCU 6-2 FCU 6-3 FCU 6-4	FXFQ40AVM FXFQ40AVM FXFQ32AVM FXAQ25PVE	E001050 E004953 E005380 E045066	Waiting Area Multi Purpose Room Staff Rest Room Server Room
Daikin	CU 7	RXMQ5AVE	E005088	FCU 7-1 FCU 7-2 FCU 7-3	FXFQ40AVM FXFQ32AVM FXFQ50AVM	E004966 E005658 E008403	Staff Rest Room BME Room Water Treatment Room
Daikin	CU 8	RXMQ5AVE	E005092	FCU 8-1 FCU 8-2 FCU 8-3	FXFQ50AVM FXFQ40AVM FXFQ32AVM	E008399 E004955 E005511	Water Treatment Room External Main Store CME Room Corridor



46. 113 Teck Whye DC (20 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RZR50LVVM	E007012	FCU 1	FCQ50LUV1	E007240	Treatment Area (Station 13)
Daikin	CU 2	RZR50LVVM	E005611	FCU 2	FCQ50LUV1	E006101	Treatment Area (Station 10, 11 & 12)
Daikin	CU 3	RZR60LVVM	E007497	FCU 3	FCQ60LUV1	E007620	Treatment Area (Station 14 & 15)
Daikin	CU 4	RZR50LVVM	E007011	FCU 4	FCQ50LUV1	E007289	Treatment Area (Station 8 & 9)
Daikin	CU 5/6	RXMQ4AVE	E005605	FCU 5 FCU 6	FXFQ50AVM FXFQ50AVM	E004176 E004178	Nurse Counter Treatment Area (Station 6 & 7)
Daikin	CU 7/9	4MKS80FSG	E005619	FCU 7 FCU 9	FFQ50BV1B FFQ50BV1B	E017045 E017039	Treatment Area (Station 5) Treatment Area (Station 16)
Daikin	CU 8/10	RXMQ4AAVEG	E000957	FCU 8 FCU 10	FXFQ50AVM FXFQ32AVM	E020011 E011873	Treatment Area (Station 18) Treatment Area (Station 3)
Daikin	CU 11	RKS35AVMG	E000925	FCU 11	FFQ35BV1B	E005075	Treatment Area (Station 1)
Daikin	CU 12	RZR60LVVM	E007342	FCU 12	FCQ60LUV1	E007353	Clean Utilities 1
Daikin	CU 13	RZR71LVVMG	E004394	FCU 13	FCQ71LUV1	E025469	Waiting Area (near Treatment)
Daikin	CU 14	RZR71LVVMG	E005130	FCU 14	FCQ71LUV1	E025473	Waiting Area (near Staff Area)
Daikin	CU 15	RZR50LVVM	E010572	FCU15	FCQ50LUV1	E009973	Staff Rest Room
Daikin	CU 17	RXMQ4AAVEG	E001219	FCU 17 FCU 17B	FXFQ50AVM FXFQ50AVM	E027584 E027649	Consultation Room Clean Utilities 3
Daikin	CU 18	RKS35LVMG	E000399	FCU 18	FTKS35LVMG	E000484	BME Room
Daikin	CU19	RKS50GVMG	E042733	FCU 19	FTKS50GVMG	E040734	Water Treatment Room
Daikin	CU 20	RKS50AVMG	E000925	FCU 20	FTKS50GVMG	E000442	Water Treatment Room

47. 701 West Coast DC (22 nos.)

Brand	Condenser	Model	Serial	FCU No.	Fan Coil	Serial	Location
Daikin	CU 1	RXMQ4AVE	E004010	FCU 1	FXFQ40SVM	C000457	Station 14
Daikin	CU 2	RXMQ4AVE	E004011	FCU 2-1 FCU 2-2	FXFQ40SVM FXFQ40SVM	C000462 C000459	Main Entrance to Area 1 Treatment Area (Station 1 & 13)
Daikin	CU 3	RXMQ5AAVEG	E002199	FCU 3-1 FCU 3-2 FCU 3-3	FXFQ40AVM FXFQ40AVM FXFQ40AVM	E016267 E016266 E015168	Treatment Area (Station 5 & 9) Treatment Area (Station 19) Treatment Area (Station 16)
Daikin	CU 4	RXMQ5AVE	E002370	FCU 4-1 FCU 4-2 FCU 4-3	FXFQ40SVM FXFQ40SVM FXFQ40SVM	C000464 C000438 C000440	Storage Cabinet Treatment Area (Station 17) Treatment Area (Station 2 & 11)
Daikin	CU 5	RZR50LVVM	E006102	FCU 5-1 FCU 5-2	FCQ50LUV1 FXFQ40SVM	E006402 C000468	Nurse Counter Treatment Area (Station 7)
Daikin	CU 6	RKS25GVMG	E034025	FCU 6	FFQ25BV1B	E007692	Solution Store
Daikin	CU 7	RXMQ4AVE	E004120	FCU 7-1 FCU 7-2	FXFQ32LUV1 FXAQ50PVE	E009050 E028871	BME Room Water Treatment Room (Near Entrance)
Daikin	CU 8	RXMQ4AVE	E004128	FCU 8-1 FCU 8-2	FXAQ50PVE FXFQ50LUV1	E028878 E016734	Water Treatment Room Outside Consultation Room
Daikin	CU 9	RXMQ5AVE	E002383	FCU 9-1 FCU 9-2 FCU 9-3	FXFQ50LUV1 FXAQ25PVE FXFQ50LUV1	E018739 E032288 E016742	Main Entrance to Area 2 Nurse Manager's Room Main Store / External Store
Daikin	CU 10	RXMQ5AVE	E002402	FCU 10-1 FCU 10-2 FCU 10-3	FXFQ32LUV1 FXFQ32LUV1 FXFQ50LUV1	E009046 E009047 E016737	Consultation Room Outside BME Room Staff Rest Room

701 West Coast Mechanical Ventilation Fan List (09 nos.)

Fan No	Model	Air Flow	Control	Location	Remark
EAF 1-1	RS125L		Int.Lock Light	Toilets	
EAF 1-2	RS125L		Int.Lock Light	Toilets	
EAF 1-3	RS125L		Int.Lock Light	Handicap Toilet	
EAF 1-4	RS125L		Int.Lock Light	Toilets	
EAF 1-5	RS125L		Int.Lock Light	Wash Area	
FAF 1-1	RS125L		Int.Lock Light	Corridor	
FAF 1-1	RS125L		Int.Lock Light	Patient Main Waiting Area	
FAF 1-3	RS125L		Int.Lock FCU	Waiting Area	
FAF 1-3	RS125L		Int.Lock FCU	Entrance beside Main	